



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3631
Engr. Ubaid

To: Mr. M. Haroon Ch. (Site Admin)
Safiya Homes Private Limited.

Project: Nil

Our Ref. No. CL/CED/ 9454

Dated: 8/1/2022

Test Specification

Your Ref. No. LHE/OHT/001

Dated: 7/28/2022

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **28/07/2022** Tested on: **7/28/2022** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	400ml Per Bag	30	6	2022	6x6x6	---	8.2	36	86	5351	---	Non Engraved
2	2nd 400ml Per Bag	30	6	2022	6x6x6	---	8.4	36	84	5227	---	Non Engraved
3	3rd 400ml Per Bag	30	6	2022	6x6x6	---	8.6	36	99	6160	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. Sarmad Niaz, CNIC # 33302-9569108-7

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6" dia x 12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3658
Dr. Umbreen

To: Engr. Amer
Prime Builders, 44 MM Alam Road, Block B1, Gulberg III, Lahore.

Project: Construction of B-45 Gulberg III, Lahore.

Our Ref. No. CL/CED/ 9455

Dated: 8/1/2022


Test Specification

Your Ref. No. Nil

Dated: 8/1/2022

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 1/8/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	4000 Psi	2	7	2022	6Diax12	---	13.5	28.28	88	6970	---	Non Engraved
2	4000 Psi	2	7	2022	6Diax12	---	13.2	28.28	81	6416	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. M. Uzair, CNIC # 16102-67846389

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3649
Dr. Umbreen

To: Mr. Muhammad Shahbaz
Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9456A

Dated: 8/1/2022


Test Specification

Your Ref. No. IHPL/Con/858

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	4000 Psi	30	6	2022	6Diax12	---	14	28.28	55	4356	---	Non Engraved
2	4000 Psi	30	6	2022	6Diax12	---	13	28.28	57	4515	---	Non Engraved
3	4000 Psi	30	6	2022	6Diax12	---	13.6	28.28	69	5465	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3649
Dr. Umbreen

To: Mr. Muhammad Shahbaz
Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9457A

Dated: 8/1/2022


Test Specification

Your Ref. No. IHPL/Con/857

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	5000 Psi	29	6	2022	6Diax12	---	13.6	28.28	77	6099	---	Non Engraved
2	5000 Psi	29	6	2022	6Diax12	---	13.8	28.28	51	4040	---	Non Engraved
3	5000 Psi	29	6	2022	6Diax12	---	13.6	28.28	73	5782	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3649
Dr. Umbreen

To: Mr. Muhammad Shahbaz
Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9458A

Dated: 8/1/2022


Test Specification

Your Ref. No. IHPL/Con/856

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	4000 Psi	27	6	2022	6Diax12	---	14	28.28	71	5624	---	Non Engraved
2	4000 Psi	27	6	2022	6Diax12	---	14	28.28	67	5307	---	Non Engraved
3	4000 Psi	27	6	2022	6Diax12	---	13.8	28.28	63	4990	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3649
Dr. Umbreen

To: Mr. Muhammad Shahbaz
Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9459A

Dated: 8/1/2022


Test Specification

Your Ref. No. IHPL/Con/855

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	5000 Psi	27	6	2022	6Diax12	---	13.4	28.28	73	5782	---	Non Engraved
2	5000 Psi	27	6	2022	6Diax12	---	13.8	28.28	75	5941	---	Non Engraved
3	5000 Psi	27	6	2022	6Diax12	---	14	28.28	81	6416	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3649
Dr. Umbreen

To: Mr. Muhammad Shahbaz
Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9460A

Dated: 8/1/2022


Test Specification

Your Ref. No. IHPL/Con/854

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	5000 Psi	26	6	2022	6Diax12	---	14.2	28.28	83	6574	---	Non Engraved
2	5000 Psi	26	6	2022	6Diax12	---	13.2	28.28	79	6257	---	Non Engraved
3	5000 Psi	26	6	2022	6Diax12	---	14.4	28.28	75	5941	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

3649
 Dr. Umbreen

To: Mr. Muhammad Shahbaz
 Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9461A

Dated: 8/1/2022

Test Specification

Your Ref. No. IHPL/Con/853

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 **Tested on:** 8/1/2022 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	4000 Psi	25	6	2022	6Diax12	---	13.4	28.28	61	4832	---	Non Engraved
2	4000 Psi	25	6	2022	6Diax12	---	13.8	28.28	65	5149	---	Non Engraved
3	4000 Psi	25	6	2022	6Diax12	---	13.8	28.28	63	4990	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3649
Dr. Umbreen

To: Mr. Muhammad Shahbaz
Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9462A

Dated: 8/1/2022


Test Specification

Your Ref. No. IHPL/Con/852

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	5000 Psi	25	6	2022	6Diax12	---	14.4	28.28	90	7129	---	Non Engraved
2	5000 Psi	25	6	2022	6Diax12	---	14	28.28	81	6416	---	Non Engraved
3	5000 Psi	25	6	2022	6Diax12	---	14	28.28	86	6812	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3649
Dr. Umbreen

To: Mr. Muhammad Shahbaz
Imperium Hospitality (PVT) Ltd.

Project: Nil

Our Ref. No. CL/CED/ 9463A

Dated: 8/1/2022


Test Specification

Your Ref. No. IHPL/Con/851

Dated: 26/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	5000 Psi	24	6	2022	6Diax12	---	14	28.28	73	5782	---	Non Engraved
2	5000 Psi	24	6	2022	6Diax12	---	13.4	28.28	86	6812	---	Non Engraved
3	5000 Psi	24	6	2022	6Diax12	---	13.6	28.28	71	5624	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Engr. Rafi Ullah Bajwa

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3648
Dr. Umbreen

To: Engr. Zaheer ud din Babar
Deputy General Manager Projects, Habib Rafiq Engineering (Pvt) Ltd., 13 H, Gulberg-II, Lahore

Project: Construction of Sky Gardens Tower, Lahore

Our Ref. No. CL/CED/ 9465A

Dated: 8/1/2022


Test Specification

Your Ref. No. HRLE/SKG/2022/056

Dated: 29/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	RCC Raft 6th Pour (6000 Psi)	2	7	2022	6Diax12	---	13	28.28	88	6970	---	Non Engraved
2	RCC Raft 6th Pour (6000 Psi)	2	7	2022	6Diax12	---	13	28.28	86	6812	---	Non Engraved
3	RCC Raft 6th Pour (6000 Psi)	2	7	2022	6Diax12	---	13.8	28.28	96	7604	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3642
Dr. Umbreen

To: Prof. Dr. Engr. Abdullah Yasar
Campus Engineer, GC University, Lahore.

Project: Construction of Sheikh Abul Hasan Al-Shadhili Research Centre on Sufism, Science & Technology, GC University, Kala Shah Kaku Campus, Lahore.

Our Ref. No. CL/CED/ 9466

Dated: 8/1/2022


Test Specification

Your Ref. No. GCU/Engr/3000/P

Dated: 28/7/2022

(BS 1881-116)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Concrete Cube (1:2:4)	1	7	2022	6x6x6	---	8.2	36	55	3422	---	Engraved
2	---	---	---	---	---	---	---	---	---	---	---	---
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6" dia x 12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3647
Dr. Umbreen

To: Mr. Muhammad Sohail Anjum
Project Manager, MS Tower, J4 Lahore.

Project: Construction of MS Tower at Plot 450,451 Johar Town Lahore.

Our Ref. No. CL/CED/ 9467A

Dated: 8/1/2022


Test Specification

Your Ref. No. MST/UET/2022/C-037

Dated: 29/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	#21 (3000 Psi)	2	7	2022	6Diax12	---	13	28.28	41	3248	---	Non Engraved
2	#23 (3000 Psi)	2	7	2022	6Diax12	---	13	28.28	39	3089	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3652
Dr. Umbreen

To: Mr. Muhammad Sohail Anjum
Project Manager, MS Tower, J4 Lahore.

Project: Construction of MS Tower at Plot 450,451 Johar Town Lahore.

Our Ref. No. CL/CED/ 9468

Dated: 8/1/2022


Test Specification

Your Ref. No. MST/UET/2022/C-038

Dated: 29/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(3000 Psi)	24	6	2022	6Diax12	---	13.4	28.28	53	4198	---	Non Engraved
2	(3000 Psi)	24	6	2022	6Diax12	---	13.4	28.28	73	5782	---	Non Engraved
3	(3000 Psi)	24	6	2022	6Diax12	---	13.8	28.28	49	3881	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3646
Dr. Umbreen

To: Mr. Shoaib A. Atallah, GM (City Project)
Vision Developers (Pvt) Ltd. 55C, Gulberg-III, Lahore.

Project: Construction of Farm House.

Our Ref. No. CL/CED/ 9469A

Dated: 8/1/2022


Test Specification

Your Ref. No. VD/CP/006/27072022

Dated: 27/7/2022

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Slab (3000 Psi)	16	6	2022	6Diax12	---	14.2	28.28	69	5465	---	Non Engraved
2	Slab (3000 Psi)	16	6	2022	6Diax12	---	14	28.28	65	5149	---	Non Engraved
3	Slab (3000 Psi)	16	6	2022	6Diax12	---	13.6	28.28	65	5149	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore. Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

3564
Dr. Umbreen

To: Mr. Shahzad Muneer
Team Leader, G3 Engineering Consultants (Pvt) Ltd.

Project: Completion of Schemes Under Community Development Programme in Sahiwal Division (GS No 7126) UC Subhan Shah Chak No. 28/D, 30/D, 27/D & 18/D (Depalpur).

Our Ref. No. CL/CED/ 9470A

Dated: 8/1/2022


Test Specification

Your Ref. No. G3/0265/TPV/14

Dated: 7/15/2022

(---)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 15/7/2022 Tested on: 8/1/2022 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Uni Block, Grey, 60mm	---	---	---	2.3 thick	---	3345	36.44	114	7008	---	Used Sample
2	Uni Block, Grey, 60mm	---	---	---	2.3 thick	---	3355	36.44	122	7499	---	Used Sample
3	Uni Block, Grey, 60mm	---	---	---	2.3 thick	---	3380	36.44	104	6393	---	Used Sample
4	Uni Block, Grey, 60mm	---	---	---	2.3 thick	---	3405	36.44	106	6516	---	Used Sample
5	Uni Block, Grey, 60mm	---	---	---	2.3 thick	---	3300	36.44	128	7868	---	Used Sample
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory