



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4156
 Dr. Aqsa

To: Mr. Arif Siddique
 Ideal Construction Service

Project: Construction of FMH Tower Lahore

Our Ref. No. CL/CED/ 232

Dated: 01-11-22

Test Specification

Your Ref. No. ICS/786/457

Dated: 28-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 28-10-22 Tested on: 01-11-22 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	20	10	2022	6Diax12	---	13.4	28.28	57	4515	---	Non Engraved
2	---	20	10	2022	6Diax12	---	13.6	28.28	51	4040	---	Non Engraved
3	---	20	10	2022	6Diax12	---	13.2	28.28	53	4198	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4156
 Dr. Aqsa

To: Mr. Arif Siddique
 Ideal Construction Service

Project: Construction of FMH Tower Lahore

Our Ref. No. CL/CED/ 233

Dated: 01-11-22

Test Specification

Your Ref. No. ICS/786/458

Dated: 28-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **28-10-22** Tested on: **01-11-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	28	9	2022	6Diax12	---	14	28.28	86	6812	---	Non Engraved
2	---	28	9	2022	6Diax12	---	13.6	28.28	78	6178	---	Non Engraved
3	---	28	9	2022	6Diax12	---	14	28.28	80	6337	---	Non Engraved
4	---	30	9	2022	6Diax12	---	13.2	28.28	82	6495	---	Non Engraved
5	---	30	9	2022	6Diax12	---	13.4	28.28	78	6178	---	Non Engraved
6	---	30	9	2022	6Diax12	---	13.6	28.28	77	6099	---	Non Engraved
7	---	3	10	2022	6Diax12	---	14.2	28.28	94	7446	---	Non Engraved
8	---	3	10	2022	6Diax12	---	14	28.28	85	6733	---	Non Engraved
9	---	3	10	2022	6Diax12	---	13.6	28.28	81	6416	---	Non Engraved
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4149
 Dr. Aqsa

To: (Mr. Muhammad Zubair Ahmed) A/XEN (B&R)
 Garrison Engineering (NAVY) Naval Complex Walton, Gulberg-III Lahore

Project: CA No. ENC-N-73/2021 - Construction of Sports Complex at PNWC Walton Lahore

Our Ref. No. CL/CED/ 234

Dated: 01-11-22

Test Specification

Your Ref. No. 6024/24/93/E-6

Dated: 26-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **27-10-22** Tested on: **01-11-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Plinth Beam	25	8	2022	6Diax12	---	13.2	28.28	61	4832	---	Non Engraved
2	Plinth Beam	25	8	2022	6Diax12	---	13.2	28.28	70	5545	---	Non Engraved
3	Plinth Beam	25	8	2022	6Diax12	---	13.4	28.28	83	6574	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4149
 Dr. Aqsa

To: (Mr. Muhammad Zubair Ahmed) A/XEN (B&R)
 Garrison Engineering (NAVY) Naval Complex Walton, Gulberg-III Lahore
Project: CA No. ENC-N-72/2021 - Construction of Children School (G+1 with G+3 Foundation) at Walton Lahore
Our Ref. No. CL/CED/ 235 **Dated:** 01-11-22
Your Ref. No. 6023/988/82/E-6 **Dated:** 26-10-22

Test Specification
 (ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **27-10-22** Tested on: **01-11-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Plinth Beam	20	9	2022	6Diax12	---	13.8	28.28	74	5861	---	Non Engraved
2	Plinth Beam	20	9	2022	6Diax12	---	14	28.28	71	5624	---	Non Engraved
3	Plinth Beam	20	9	2022	6Diax12	---	13	28.28	77	6099	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4107
 Dr. Aqsa

To: Sub Divisional Officer
 Buildings Sub Division No. 20, Lahore

Project: Construction of Office Building of Chief Inspectorate of Mines Punjab (ADP No. 4556 for Year 2022-2023)

Our Ref. No. CL/CED/ 236

Dated: 01-11-22

Test Specification

Your Ref. No. 424/20th

Dated: 17-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **20-10-22** Tested on: **01-11-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	R.C.C. Columns G/F (1:1-1/2:3)	20	9	2022	6Diax12	---	12.6	28.28	57	4515	---	Non Engraved
2	R.C.C. Columns G/F (1:1-1/2:3)	20	9	2022	6Diax12	---	13.8	28.28	61	4832	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4107
 Dr. Aqsa

To: Sub Divisional Officer
 Buildings Sub Division No. 20, Lahore

Project: Construction of Office Building of Chief Inspectorate of Mines Punjab (ADP No. 4556 for Year 2022-2023)

Our Ref. No. CL/CED/ 237

Dated: 01-11-22

Test Specification

Your Ref. No. 422/20th

Dated: 13-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 20-10-22 **Tested on:** 01-11-22 **in dry/wet condition**

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	R.C.C. Basement Roof (1:2:4)	15	9	2022	6Diax12	---	13	28.28	65	5149	---	Non Engraved
2	R.C.C. Basement Roof (1:2:4)	15	9	2022	6Diax12	---	13.2	28.28	81	6416	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4138
 Dr. Aqsa

To: Engr. Zafar Iqbal, PM
 For United Life Styles (Pvt.) Ltd.

Project: Skyscraper by United LifeStyle Johar Town, Lahore.

Our Ref. No. CL/CED/ 238

Dated: 01-11-22

Test Specification

Your Ref. No. ULS/2021-22/002

Dated: 25-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **26-10-22** Tested on: **01-11-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*				Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY									
1	---	24	9	2022	6Diax12	---	13.4	28.28	63	4990	---	Non Engraved	
2	---	24	9	2022	6Diax12	---	13.2	28.28	74	5861	---	Non Engraved	
3	---	---	---	---	---	---	---	---	---	---	---	---	
4	---	---	---	---	---	---	---	---	---	---	---	---	
5	---	---	---	---	---	---	---	---	---	---	---	---	
6	---	---	---	---	---	---	---	---	---	---	---	---	
7	---	---	---	---	---	---	---	---	---	---	---	---	
8	---	---	---	---	---	---	---	---	---	---	---	---	
9	---	---	---	---	---	---	---	---	---	---	---	---	
10	---	---	---	---	---	---	---	---	---	---	---	---	
11	---	---	---	---	---	---	---	---	---	---	---	---	
12	---	---	---	---	---	---	---	---	---	---	---	---	
13	---	---	---	---	---	---	---	---	---	---	---	---	
14	---	---	---	---	---	---	---	---	---	---	---	---	
15	---	---	---	---	---	---	---	---	---	---	---	---	
16	---	---	---	---	---	---	---	---	---	---	---	---	

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4163
 Dr. Aqsa

To: Mr. Maqsood Alam, Senior Manager (Civil)
 Systems Ltd. Lahore

Project: Rear Tower Systems Ltd.

Our Ref. No. CL/CED/ 239

Dated: 01-11-22

Test Specification

Your Ref. No. SYS-RT-UET-0012

Dated: 31-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 31-10-22 Tested on: 01-11-22 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	4th Floor Column	1	10	2022	6Diax12	---	14.6	28.28	83	6574	---	Non Engraved
2	4th Floor Column	1	10	2022	6Diax12	---	14.2	28.28	74	5861	---	Non Engraved
3	4th Floor Column	1	10	2022	6Diax12	---	14.2	28.28	76	6020	---	Non Engraved
4	4th Floor Column	1	10	2022	6Diax12	---	14	28.28	70	5545	---	Non Engraved
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4162
 Dr. Aqsa

To: Engr. Zaheer Ud Din Babar, Dy. GM Projects
 Habib Rafiq Engineering Pvt. Ltd.

Project: Construction of Sky Gardens Tower, Lahore

Our Ref. No. CL/CED/ 240

Dated: 01-11-22

Test Specification

Your Ref. No. HRLE/SKG/2022/080

Dated: 31-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **31-10-22** Tested on: **01-11-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	RCC Raft 242,14th Pour (6000Psi)	29	10	2022	6Diax12	---	14	28.28	83	6574	---	Non Engraved
2	RCC Raft 242,14th Pour (6000Psi)	29	10	2022	6Diax12	---	14	28.28	83	6574	---	Non Engraved
3	RCC Raft 242,14th Pour (6000Psi)	29	10	2022	6Diax12	---	14	28.28	84	6653	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4115
 Dr. Mazhar

To: Executive Engineer
 Qadirabad Balloki Link Canal Division, Farooqabad.

Project: Construction of New QB Link Office Complex Residences and Boundary Wall at Farooqabad.

Our Ref. No. CL/CED/ 241- 1 of 2

Dated: 01-11-22

Test Specification

Your Ref. No. 942/7-G-I

Dated: 21-10-22

(ASTM C39)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **21-10-22** Tested on: **27-10-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	15	9	2022	6Diax12	---	13	28.28	29	2297	---	Engraved
2	---	15	9	2022	6Diax12	---	13	28.28	23	1822	---	Engraved
3	---	15	9	2022	6Diax12	---	13	28.28	24	1901	---	Engraved
4	---	15	9	2022	6Diax12	---	13	28.28	30	2376	---	Engraved
5	---	19	9	2022	6Diax12	---	12.8	28.28	16	1267	---	Engraved
6	---	19	9	2022	6Diax12	---	12.4	28.28	17	1347	---	Engraved
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. Abdullah (Nespak), CNIC # 35201-4533740-9

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

4115
 Dr. Mazhar

To: Executive Engineer
 Qadirabad Balloki Link Canal Division, Farooqabad.

Project: Construction of New QB Link Office Complex Residences and Boundary Wall at Farooqabad.

Our Ref. No. CL/CED/ 241- 2 of 2

Dated: 01-11-22

Test Specification

Your Ref. No. 942/7-G-I

Dated: 21-10-22

(BS 1881-116)

COMPRESSION TEST REPORT



ONLINE REPORT

Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **21-10-22** Tested on: **27-10-22** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	15	9	2022	6x6x6	---	8.2	36	49	3049	---	Engraved
2	---	15	9	2022	6x6x6	---	8	36	47	2924	---	Engraved
3	---	15	9	2022	6x6x6	---	8	36	31	1929	---	Non Engraved
4	---	19	9	2022	6x6x6	---	8	36	23	1431	---	Engraved
5	---	19	9	2022	6x6x6	---	8	36	31	1929	---	Engraved
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. Abdullah (NESPAK), CNIC # 35201-4533740-9

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

1. * as engraved on the specimens (if any)
2. ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
3. *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
4. **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

1. The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
2. The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory