



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8826
Dr. Aqsa

To: Mr. Syed Usman Ali
Air Heights Developers (Pvt) Ltd

Project: DE VIEW located at 72-Attaturk Block, New Garden Town Lahore (2nd Floor Columns & Lift)

Our Ref. No. CL/CED/ 7337

Dated: 12/02/2025

Test Specification

Your Ref. No. Nil

Dated: 04/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 04/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	4000 Psi	27	1	2025	6Diax12	---	13	28.28	46	3644	---	Non Engraved
2	4000 Psi	27	1	2025	6Diax12	---	13.8	28.28	59	4673	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8827

Dr. Aqsa

To: Mr. Muhammad Saleem
GM, Professional Construction Services (Pvt) Ltd.

Project: Construction of TCF Primary School Taunsa Sharif DG Khan

Our Ref. No. CL/CED/ 7338

Dated: 12/02/2025

Test Specification

Your Ref. No. PCS/25/Eng-16

Dated: 04/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 04/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	Footing	4	1	2025	6Diax12	---	13.2	28.28	74	5861	---	Non Engraved
2	---	---	---	---	---	---	---	---	---	---	---	---
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8827
Dr. Aqsa

To: Mr. Muhammad Saleem
GM, Professional Construction Services (Pvt) Ltd

Project: Construction of TCF Primary School Taunsa Sharif DG Khan

Our Ref. No. CL/CED/ 7339

Dated: 12/02/2025

Test Specification

Your Ref. No. PCS/25/Eng-15B

Dated: 04/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 04/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	Footing	4	1	2025	6Diax12	---	13	28.28	44	3485	---	Non Engraved
2	---	---	---	---	---	---	---	---	---	---	---	---
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8823

Dr. Aqsa

To: Mr. Manzoor Ahmad Joya
Resident Engineer, NESPAK (Pvt) Ltd

Project: Establishment of Labour Colony at Quaid-e-Azam Business Park, M2-Motorway, District Sheikhupura; Construction of Bachelors Hostel (Contract Package-A)

Our Ref. No. CL/CED/ 7340

Dated: 12/02/2025

Test Specification

Your Ref. No. 3844/311/RE/051

Dated: 01/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 04/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	R01	5	1	2025	6Diax12	---	13.4	28.28	19	1505	---	Engraved
2	R01	5	1	2025	6Diax12	---	13.4	28.28	22	1743	---	Engraved
3	R01	5	1	2025	6Diax12	---	13.2	28.28	18	1426	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8843
Dr. Aqsa

To: Mr. Safdar Rashid
Resident Engineer, Consulting Engineers- Architecture & Planning Division, NESPAK (Pvt) Ltd
Project: KBCMA College of Veterinary and Animal Sciences Narowal Campus (BS 18-19 Residences) (Activity: Roof Slab)
Our Ref. No. CL/CED/ 7341
Your Ref. No. 4650/311/SR/95

Dated: 12/02/2025

Test Specification

Dated: 04/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 06/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	GF Slab (1:1.5:3)	9	1	2025	6Diax12	---	14	28.28	34	2693	---	Non Engraved
2	GF Slab (1:1.5:3)	9	1	2025	6Diax12	---	13.6	28.28	44	3485	---	Non Engraved
3	GF Slab (1:1.5:3)	9	1	2025	6Diax12	---	13.6	28.28	38	3010	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8824
Dr. Aqsa

To: Mr. Waqas Asif
Director, ICON CONSTRUCTION SERVICES

Project: Fauzia and Harris Residence at Green Fort Lahore.

Our Ref. No. CL/CED/ 7342

Dated: 12/02/2025

Test Specification

Your Ref. No. Nil

Dated: 03/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 04/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	4000 Psi	13	1	2025	6Diax12	---	13	28.28	39	3089	---	Engraved
2	4000 Psi	13	1	2025	6Diax12	---	14	28.28	43	3406	---	Engraved
3	4000 Psi	13	1	2025	6Diax12	---	14.2	28.28	39	3089	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8884
Dr. Aqsa

To: Mr. Abdul Baseet
Material Engineer, Banu Mukhtar Contracting (Pvt) Ltd
Project: Burj-1 by AJWA Builders (Shear Wall-03, Grid F-G/9 Column # 06Nos, Grid C,D/7, F, G/7,H/7,9)- Main Building 8th Floor Zone-02
Our Ref. No. CL/CED/ 7343
Your Ref. No. DOC-BMC/AJWA/181

Dated: 12/02/2025

Test Specification

Dated: 11/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 11/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	6000 Psi	12	1	2025	6Diax12	---	14	28.28	95	7525	---	Non Engraved
2	6000 Psi	12	1	2025	6Diax12	---	14.2	28.28	126	9980	---	Non Engraved
3	6000 Psi	12	1	2025	6Diax12	---	14.6	28.28	122	9663	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8884

Dr. Aqsa

To: Mr. Abdul Baseet

Material Engineer, Banu Mukhtar Contracting (Pvt) Ltd

Project: Burj-1 by AJWA Builders (Lift Wall-05 Grid H-H'/4, Lift Wall-01 Grid H-H'/6, Shear Wall-04 Grid F-G/9)-
Main Building 7th Floor Zone-02 & 8th Floor Zone-02

Our Ref. No. CL/CED/ 7344

Dated: 12/02/2025

Test Specification

Your Ref. No. DOC-BMC/AJWA/180

Dated: 11/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 11/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	6000 Psi	9	1	2025	6Diax12	---	14.6	28.28	129	10218	---	Non Engraved
2	6000 Psi	9	1	2025	6Diax12	---	14	28.28	100	7921	---	Non Engraved
3	6000 Psi	9	1	2025	6Diax12	---	14.2	28.28	106	8396	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8848
Dr. Aqsa

To: Mr. Abdul Baseet
Material Engineer, Banu Mukhtar Contracting (Pvt) Ltd
Project: Burj-1 by AJWA Builders (Lift Wall-03 Grid H'-H/5, Column #05 Grid F, G/7,8, H'/8)- Main Building 7th Floor Zone-02
Our Ref. No. CL/CED/ 7345
Your Ref. No. DOC-BMC/AJWA/179

Dated: 12/02/2025

Test Specification

Dated: 06/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 06/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	6000 Psi	6	1	2025	6Diax12	---	14.4	28.28	107	8475	---	Non Engraved
2	6000 Psi	6	1	2025	6Diax12	---	14.6	28.28	111	8792	---	Non Engraved
3	6000 Psi	6	1	2025	6Diax12	---	14.2	28.28	94	7446	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8806
Dr. Aqsa

To: Al-Hadeed Corporation
Liberty Tower, Lahore.

Project: Construction of Shell Petrol Pump at Yateem Khana, Lahore

Our Ref. No. CL/CED/ 7346

Dated: 12/02/2025

Test Specification

Your Ref. No. AHC/554/10

Dated: 03/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 03/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	---	16	1	2025	6Diax12	---	14	28.28	46	3644	---	Non Engraved
2	---	16	1	2025	6Diax12	---	13.2	28.28	39	3089	---	Non Engraved
3	---	16	1	2025	6Diax12	---	13.6	28.28	58	4594	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8806
Dr. Aqsa

To: Al-Hadeed Corporation
Liberty Tower, Lahore.

Project: Construction of Shell Petrol Pump at Yateem Khana, Lahore

Our Ref. No. CL/CED/ 7347

Dated: 12/02/2025

Test Specification

Your Ref. No. AHC/554/10

Dated: 03/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 03/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	---	18	1	2025	6Diax12	---	13.6	28.28	42	3327	---	Non Engraved
2	---	18	1	2025	6Diax12	---	13.8	28.28	67	5307	---	Non Engraved
3	---	18	1	2025	6Diax12	---	14	28.28	49	3881	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for
the report has
been retained in
the lab for record.

8792
Dr. Aqsa

To: **Mr. KAMRAN KHAN**
Procurement Manager, Q-Links Construction

Project: Construction of Orchard Mall, Bahria Town Lahore (Septic Tank RCC)

Our Ref. No. CL/CED/ 7348

Dated: 12/02/2025

Test Specification

Your Ref. No. QLC-O.M-2024-LT FGK-15

Dated: 30/1/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/1/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	4000 Psi	22	1	2025	6Diax12	---	14	28.28	64	5069	---	Non Engraved
2	---	---	---	---	---	---	---	---	---	---	---	---
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

8792
Dr. Aqsa

To: **Mr. KAMRAN KHAN**
Procurement Manager, Q-Links Construction

Project: Construction of Gold Souq, Bahria Town Lahore (Roof Slab Basement Grid 5-6/BC)

Our Ref. No. CL/CED/ 7349

Dated: 12/02/2025

Test Specification

Your Ref. No. QLC-O.M-2024-LT FGK-14

Dated: 30/1/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/1/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	3500 Psi	18	1	2025	6Diax12	---	14	28.28	38	3010	---	Non Engraved
2	3500 Psi	18	1	2025	6Diax12	---	14	28.28	54	4277	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8867
Dr. Safeer

To: Mr. Mahbub ur Rehman
Project Manager, 7Canal Developers, Gulberg 2, Lahore.

Project: 7 Canal Residential Apartment Buildings

Our Ref. No. CL/CED/ 7350

Dated: 12/02/2025

Test Specification

Your Ref. No. Nil

Dated: 10/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	---	2	2	2025	6Diax12	---	14	28.28	42	3327	---	Engraved
2	---	2	2	2025	6Diax12	---	14.2	28.28	44	3485	---	Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. Mahbub Butt, CNIC 34202-1043359-7

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

8845
Dr. Wasim

To: Mr. Mahbub ur Rehman
Project Manager, 7 Canal Developers, Gulberg 2, Lahore

Project: 7 Canal Residential Apartment Buildings

Our Ref. No. CL/CED/ 7351

Dated: 12/02/2025

Test Specification

Your Ref. No. Nil

Dated: 06/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 06/02/2025 Tested on: 10/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	6	12	2024	6Diax12	---	14.5	28.28	103	8158	---	Non Engraved
2	---	6	12	2024	6Diax12	---	15	28.28	85	6733	---	Non Engraved
3	---	12	12	2024	6Diax12	---	14.6	28.28	97	7683	---	Non Engraved
4	---	12	12	2024	6Diax12	---	14.2	28.28	83	6574	---	Non Engraved
5	---	26	1	2025	6Diax12	---	14	28.28	34	2693	---	Non Engraved
6	---	26	1	2025	6Diax12	---	14	28.28	54	4277	---	Non Engraved
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. Mahbub Butt, CNIC 34202-1043359-7

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8856
Dr. Aqsa

To: Mr. Muhammad Sajjad
Project Incharge

Project: Construction of House No. 60, C Block Model Town, Lahore (5th Floor Slab)

Our Ref. No. CL/CED/ 7352

Dated: 12/02/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 7/2/2025 Tested on: 11/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	3000 Psi	1	2	2025	6Diax12	---	13	28.28	52	4119	---	Engraved
2	3000 Psi	1	2	2025	6Diax12	---	13.8	28.28	47	3723	---	Engraved
3	3000 Psi	1	2	2025	6Diax12	---	13.4	28.28	39	3089	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8850
Dr. Aqsa

To: Mr. Aziz ur Rehman
Assistant Resident Engineer, ACE Architectural & Town Planning Services Limited, Lhr
Project: Resident Construction Supervision for Construction of Net Zero Energy Building (ACEIP, DLI-8), Lahore (Admixture- Fospak 568, Admixture Water Proofing- Fospak Wp 200)
Our Ref. No. CL/CED/ 7353 Dated: 12/02/2025
Your Ref. No. NZEB/ACE/LAB/2025/13 Dated: 06/02/2025

Test Specification
(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 06/02/2025 Tested on: 11/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Lab curing (5000 Psi)	10	1	2025	6Diax12	---	14	28.28	68	5386	---	Non Engraved
2	Lab curing (5000 Psi)	10	1	2025	6Diax12	---	14	28.28	66	5228	---	Non Engraved
3	Lab curing (5000 Psi)	10	1	2025	6Diax12	---	14.2	28.28	63	4990	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8799

Dr. Aqsa

To: Mr. M. YASIR KIANI
Resident Engineer (JCP WAHGA), Architecture & Planning Division, NESPAK (Pvt) Ltd.

Project: Relocation and Enhancement of Wahga Border Flagpole

Our Ref. No. CL/CED/ 7354

Dated: 12/02/2025

Test Specification

Your Ref. No. 4749/031/YK/01/127

Dated: 30/1/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/1/2025 Tested on: 11/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	---	17	1	2025	6Diax12	---	14	28.28	51	4040	---	Non Engraved
2	---	17	1	2025	6Diax12	---	14	28.28	43	3406	---	Non Engraved
3	---	17	1	2025	6Diax12	---	14.2	28.28	43	3406	---	Non Engraved
4	---	17	1	2025	6Diax12	---	13.4	28.28	65	5149	---	Non Engraved
5	---	17	1	2025	6Diax12	---	14	28.28	56	4436	---	Non Engraved
6	---	17	1	2025	6Diax12	---	14	28.28	48	3802	---	Non Engraved
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8798

Dr. Aqsa

To: NIMIR CHEMCOAT LIMITED
New Muslim Town, Lahore.

Project: Askari Shoes AWT Site, Plot #41, Maulana Shoukat Ali Road, Quaid-e-Azam Industrial Estate Kot Lakhpat, Lahore.

Our Ref. No. CL/CED/ 7355

Dated: 12/02/2025

Test Specification

Your Ref. No. Nimir-125-Adm-105

Dated: 29/1/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/1/2025 Tested on: 11/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	Column	15	1	2025	6Diax12	---	13.6	28.28	47	3723	---	Non Engraved
2	Column	15	1	2025	6Diax12	---	13.4	28.28	44	3485	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8860
Dr. Aqsa

To: Engr. M. Imran
Resident Engineer, Master Consulting Engineers Pvt. Ltd
Project: Construction of 07-Storey Residential Block having Minimum 100 Rooms with Attached Bathroom
Facilities at Gurdwara Janamasthan, Nankana Sahib
Our Ref. No. CL/CED/ 7356
Your Ref. No. NKB/RE/RCC-40

Dated: 12/02/2025

Test Specification

Dated: 06/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 07/02/2025 Tested on: 11/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Slab 3rd Floor (1:1.5:3)	9	1	2025	6x6x6	---	9	36	73	4542	---	Engraved
2	Slab 3rd Floor (1:1.5:3)	9	1	2025	6x6x6	---	9	36	89	5538	---	Engraved
3	Slab 3rd Floor (1:1.5:3)	9	1	2025	6x6x6	---	9	36	81	5040	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8860
Dr. Aqsa

To: Engr. M. Imran
Resident Engineer, Master Consulting Engineers Pvt. Ltd
Project: Construction of 07-Storey Residential Block having Minimum 100 Rooms with Attached Bathroom
Facilities at Gurdwara Janamasthan, Nankana Sahib
Our Ref. No. CL/CED/ 7357
Your Ref. No. NKB/RE/RCC-41

Dated: 12/02/2025

Test Specification

Dated: 06/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 07/02/2025 Tested on: 11/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	Col. 4th Floor (1:1:2)	13	1	2025	6x6x6	---	9	36	114	7093	---	Engraved
2	Col. 4th Floor (1:1:2)	13	1	2025	6x6x6	---	8.8	36	108	6720	---	Engraved
3	Col. 4th Floor (1:1:2)	13	1	2025	6x6x6	---	8.8	36	106	6596	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869
Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPSKP0009 (Solar Foundation & Columns)

Our Ref. No. CL/CED/ 7358

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/65

Dated: 31/1/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	24	1	2025	6x6x6	---	8.4	36	35	2178	---	Non Engraved
2	(1:1.5:3)	24	1	2025	6x6x6	---	8.4	36	25	1556	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"x12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869

Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPPSH0011 (Solar Foundation & Columns)

Our Ref. No. CL/CED/ 7359

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/59

Dated: 09/01/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	12	12	2024	6x6x6	---	8.6	36	37	2302	---	Non Engraved
2	(1:1.5:3)	12	12	2024	6x6x6	---	8.8	36	64	3982	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869

Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPPSH0012 (Solar Foundation & Columns)

Our Ref. No. CL/CED/ 7360

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/60

Dated: 02/01/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	5	12	2024	6x6x6	---	8.6	36	37	2302	---	Non Engraved
2	(1:1.5:3)	5	12	2024	6x6x6	---	9	36	59	3671	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869
Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPPSH0018 (Solar Foundation & Columns)

Our Ref. No. CL/CED/ 7361

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/61

Dated: 06/01/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	9	12	2024	6x6x6	---	9	36	47	2924	---	Non Engraved
2	(1:1.5:3)	9	12	2024	6x6x6	---	9.2	36	76	4729	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"x12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869
Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPSWB0001 (Solar Foundation & Columns)

Our Ref. No. CL/CED/ 7362

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/62

Dated: 24/12/2024

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	26	11	2024	6x6x6	---	8.6	36	57	3547	---	Non Engraved
2	(1:1.5:3)	26	11	2024	6x6x6	---	8.6	36	57	3547	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869

Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPSFSD0008 (Solar Foundation & Columns)

Our Ref. No. CL/CED/ 7363

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/63

Dated: 14/01/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	17	12	2024	6x6x6	---	9	36	47	2924	---	Non Engraved
2	(1:1.5:3)	17	12	2024	6x6x6	---	8.8	36	57	3547	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869

Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPSFSD0009 (Solar Foundation & Columns)

Our Ref. No. CL/CED/ 7364

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/64

Dated: 12/01/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	15	12	2024	6x6x6	---	8.8	36	50	3111	---	Non Engraved
2	(1:1.5:3)	15	12	2024	6x6x6	---	8.8	36	32	1991	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"x12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8869

Dr. Aqsa

To: AJ Contractors (Pvt) Ltd
Ex Park View Lahore.

Project: TAWAL Project Site ID: TWPSKP0009 (OPU PAD)

Our Ref. No. CL/CED/ 7365

Dated: 12/02/2025

Test Specification

Your Ref. No. AJ Contractor/Cubes/Tawal/66

Dated: 02/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	26	1	2025	6x6x6	---	8.6	36	40	2489	---	Non Engraved
2	(1:1.5:3)	26	1	2025	6x6x6	---	8.4	36	47	2924	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8868
Dr. Aqsa

To: ZENITH ASSOCIATES
Town Ship Lahore.

Project: Engro Enfra Share Project Site ID: 54006 (EN2-LWD-09399)

Our Ref. No. CL/CED/ 7366

Dated: 12/02/2025

Test Specification

Your Ref. No. Zinat Associate/Cubes/Engro Enfra Share/08

Dated: 29/11/2024

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Tower Raft (1:1.5:3)	1	11	2024	6x6x6	---	8.8	36	49	3049	---	Non Engraved
2	Tower Raft (1:1.5:3)	1	11	2024	6x6x6	---	9	36	53	3298	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"x12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

8868
Dr. Aqsa

To: ZENITH ASSOCIATES
Town Ship Lahore.

Project: Engro Enfra Share Project Site ID: 54006 (EN2-LWD-09399)- (Tower Columns + ODU + DG PAD)

Our Ref. No. CL/CED/ 7367

Dated: 12/02/2025

Test Specification

Your Ref. No. Zinat Associate/Cubes/Engro Enfra Share/09

Dated: 02/12/2024

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	4	11	2024	6x6x6	---	8.6	36	60	3733	---	Non Engraved
2	(1:1.5:3)	4	11	2024	6x6x6	---	8.6	36	59	3671	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8868
Dr. Aqsa

To: ZENITH ASSOCIATES
Town Ship Lahore.

Project: Engro Enfra Share Project Site ID: NR024 CB-281 (EC2-FSD-09432) (Tower PIER + ODU + DG PAD)

Our Ref. No. CL/CED/ 7368

Dated: 12/02/2025

Test Specification

Your Ref. No. Zinat Associate/Cubes/Engro Enfra Share/10

Dated: 13/11/2024

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(1:1.5:3)	16	10	2024	6x6x6	---	8.8	36	49	3049	---	Non Engraved
2	(1:1.5:3)	16	10	2024	6x6x6	---	9	36	49	3049	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8868
Dr. Aqsa

To: ZENITH ASSOCIATES
Town Ship Lahore.

Project: Engro Enfra Share Project Site ID: NR024 CB-266 (EC2-KWL-09114) (Tower RAFT + ODU + DG PAD)

Our Ref. No. CL/CED/ 7369

Dated: 12/02/2025

Test Specification

Your Ref. No. Zinat Associate/Cubes/Engro Enfra Share/11

Dated: 14/11/2024

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	(1:1.5:3)	17	10	2024	6x6x6	---	9	36	49	3049	---	Non Engraved
2	(1:1.5:3)	17	10	2024	6x6x6	---	9	36	53	3298	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"x12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

8868
Dr. Aqsa

To: **ZENITH ASSOCIATES**
Town Ship Lahore.

Project: Engro Enfra Share Project Site ID: NR024-CB-266 (EC2-KWL-09114) (Tower Columns)

Our Ref. No. CL/CED/ 7370

Dated: 12/02/2025

Test Specification

Your Ref. No. Zinat Associate/Cubes/Engro Enfra Share/07

Dated: 17/11/2024

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(1:1.5:3)	20	10	2024	6x6x6	---	8.6	36	56	3484	---	Non Engraved
2	(1:1.5:3)	20	10	2024	6x6x6	---	8.6	36	49	3049	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"x12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8877
Dr. Aqsa

To: Sub Divisional Officer

Public Health Engg: Sub Division Sargodha

Project: Repair / Replacement of Main Sewer Line of 72" under the Bed of Lower Jhelum Canal, Sargodha (Phase I & II).

Our Ref. No. CL/CED/ 7371

Dated: 12/02/2025

Test Specification

Your Ref. No. 78/S

Dated: 03/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 11/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(1:1.5:3)	6	1	2025	6x6x6	---	8.4	36	108	6720	---	Non Engraved
2	(1:1.5:3)	6	1	2025	6x6x6	---	8.2	36	95	5911	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8876

Dr. Aqsa

To: Sub Divisional Officer
Public Health Engg: Sub Division Noor Pur Thal

Project: Construction of PCC SLAB / WATER FILTRATION PLANT in UC GUNJIAL JANUBI District KHUSHAB

Our Ref. No. CL/CED/ 7372

Dated: 12/02/2025

Test Specification

Your Ref. No. 35/N.P.T

Dated: 24/1/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 11/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(1:2:4)	7	1	2025	6x6x6	---	8.4	36	109	6782	---	Engraved
2	(1:2:4)	7	1	2025	6x6x6	---	8.2	36	120	7467	---	Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8874
Dr. Aqsa

To: Mr. Muhammad Imran
Construction Manager, ITTEFAQ Building Solutions, Johar Town Lahore.

Project: Mr. Imran Qamar Residence Cantt, Lahore (First Floor Column, Building Phase II)

Our Ref. No. CL/CED/ 7373

Dated: 12/02/2025

Test Specification

Your Ref. No. Nil

Dated: 10/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 10/02/2025 Tested on: 12/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size	Wet Weight	Dry Weight	Area of X-Section	Ultimate load	Ultimate Stress	Water Absorption (%)	Remarks
		DD	MM	YYYY	(in)	(Kg/ gms)	(Kg/ gms)	(Sq. in)	(Imp.Tons)	(psi)		
1	3500 Psi	11	1	2025	6x6x6	---	9	36	38	2364	---	Non Engraved
2	3500 Psi	11	1	2025	6x6x6	---	8.8	36	38	2364	---	Non Engraved
3	3500 Psi	11	1	2025	6x6x6	---	8.6	36	36	2240	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"x12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8811
Dr. M. Yousaf

To: A.R.E
Package V, MMP-PCP, Okara. MM Pakistan (Pvt) Ltd.

Project: Laying of Tuff Pavers/Tiles in Various Important Areas of Okara City.

Our Ref. No. CL/CED/ 7374

Dated: 12/02/2025

Test Specification

Your Ref. No. MMP/PCP/MCO/354/2025

Dated: 08/01/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 03/02/2025 Tested on: 10/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	Uni-Block, 60 mm, Grey	---	---	---	2.4 thick	---	3590	36.39	148	9110	---	---
2	Uni-Block, 60 mm, Grey	---	---	---	2.4 thick	---	3520	36.39	148	9110	---	---
3	Uni-Block, 60 mm, Grey	---	---	---	2.4 thick	---	3515	36.39	149	9172	---	---
4	Uni-Block, 60 mm, Red	---	---	---	2.4 thick	---	3590	36.39	150	9233	---	---
5	Uni-Block, 60 mm, Red	---	---	---	2.4 thick	---	3455	36.39	138	8495	---	---
6	Uni-Block, 60 mm, Red	---	---	---	2.4 thick	---	3425	36.39	153	9418	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. Waseem Ahmed Hashmi, RE MMP/AID PCP Package V

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory

Civil Engineering Department

University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL

A carbon copy for the report has been retained in the lab for record.

8811
Dr. M. Yousaf

To: A.R.E
Package V, MMP-PCP, Okara. MM Pakistan (Pvt) Ltd.

Project: Laying of Tuff Pavers/Tiles in Various Important Areas of Okara City.

Our Ref. No. CL/CED/ 7375

Dated: 12/02/2025

Test Specification

Your Ref. No. MMP/PCP/MCO/365/2025

Dated: 18/1/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 03/02/2025 Tested on: 10/02/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	Uni-Block, 80 mm, Grey	---	---	---	3.2 thick	---	4640	36.39	74	4555	---	---
2	Uni-Block, 80 mm, Grey	---	---	---	3.2 thick	---	4475	36.39	49	3016	---	---
3	Uni-Block, 80 mm, Grey	---	---	---	3.2 thick	---	4670	36.39	99	6094	---	---
4	Uni-Block, 80 mm, Red	---	---	---	3.2 thick	---	4610	36.39	80	4924	---	---
5	Uni-Block, 80 mm, Red	---	---	---	3.2 thick	---	4510	36.39	56	3447	---	---
6	Uni-Block, 80 mm, Red	---	---	---	3.2 thick	---	4535	36.39	82	5048	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Mr. Waseem Ahmed Hashmi, RE MMP/AID PCP Package V

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory