



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9626
 Dr. Umbreen

To: Mr. Ali Zahid Latif
 Principal Engineer, NESPAK (Pvt.) Ltd. Construction Management Division.(M/S Anjum Hafeez Const
Project: Enhancement & Construction of the Shrine Syed Ali-Hajveri (R.A) Data Ganj Bakhsh, Lahore.
Our Ref. No. CL/CED/ 8631 **Dated:** 20/06/2025
Your Ref. No. 4580/13/AZL/01/042 **Dated:** 04/04/2025

Test Specification
 (ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 17/06/2025 **Tested on:** 19/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	Columns, "C" (4000 Psi)	28	3	2025	6Diax12	---	13	28.28	96	7604	---	Non Engraved
2	Columns, "C" (4000 Psi)	28	3	2025	6Diax12	---	14.4	28.28	68	5386	---	Non Engraved
3	Columns, "C" (4000 Psi)	28	3	2025	6Diax12	---	14	28.28	60	4752	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9626
 Dr. Umbreen

To: Mr. Ali Zahid Latif
 Principal Engineer, NESPAK (Pvt.) Ltd. Construction Management Division.(M/S Anjum Hafeez Const
Project: Enhancement & Construction of the Shrine Syed Ali-Hajveri (R.A) Data Ganj Bakhsh, Lahore.
Our Ref. No. CL/CED/ 8632 **Dated:** 20/06/2025
Your Ref. No. 4580/13/AZL/01/043 **Dated:** 03/05/2025

Test Specification
 (ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **17/06/2025** Tested on: **19/06/2025** in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Arches, "C" (4000 Psi)	26	4	2025	6Diax12	---	14	28.28	78	6178	---	Non Engraved
2	Arches, "C" (4000 Psi)	26	4	2025	6Diax12	---	15	28.28	76	6020	---	Non Engraved
3	Arches, "C" (4000 Psi)	26	4	2025	6Diax12	---	14.6	28.28	84	6653	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9626
 Dr. Umbreen

To: Mr. Ali Zahid Latif
 Principal Engineer, NESPAK (Pvt.) Ltd. Construction Management Division.(M/S Anjum Hafeez Const)

Project: Enhancement & Construction of the Shrine Syed Ali-Hajveri (R.A) Data Ganj Bakhsh, Lahore.

Our Ref. No. CL/CED/ 8633 **Dated: 20/06/2025**

Your Ref. No. 4580/13/AZL/01/044 **Dated: 15/05/2025**

Test Specification
 (ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 17/06/2025 **Tested on:** 19/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Arches, "C" (4000 Psi)	7	5	2025	6Diax12	---	14	28.28	70	5545	---	Non Engraved
2	Arches, "C" (4000 Psi)	7	5	2025	6Diax12	---	14	28.28	68	5386	---	Non Engraved
3	Arches, "C" (4000 Psi)	7	5	2025	6Diax12	---	13.8	28.28	60	4752	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9626
 Dr. Umbreen

To: Mr. Ali Zahid Latif
 Principal Engineer, NESPAK (Pvt.) Ltd. Construction Management Division.(M/S Anjum Hafeez Const
Project: Enhancement & Construction of the Shrine Syed Ali-Hajveri (R.A) Data Ganj Bakhsh, Lahore.
Our Ref. No. CL/CED/ 8634 **Dated:** 20/06/2025
Your Ref. No. 4580/13/AZL/01/048 **Dated:** 31/05/2025

Test Specification
 (ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 17/06/2025 **Tested on:** 19/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Slab, "C" (4000 Psi)	23	5	2025	6Diax12	---	14	28.28	74	5861	---	Non Engraved
2	Slab, "C" (4000 Psi)	23	5	2025	6Diax12	---	14	28.28	78	6178	---	Non Engraved
3	Slab, "C" (4000 Psi)	23	5	2025	6Diax12	---	13.4	28.28	84	6653	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9626
 Dr. Umbreen

To: Mr. Ali Zahid Latif
 Principal Engineer, NESPAK (Pvt.) Ltd. Construction Management Division.(M/S Anjum Hafeez Const

Project: Enhancement & Construction of the Shrine Syed Ali-Hajveri (R.A) Data Ganj Bakhsh, Lahore.

Our Ref. No. CL/CED/ 8635

Dated: 20/06/2025

Test Specification

Your Ref. No. 4580/13/AZL/01/049

Dated: 05/06/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 17/06/2025 **Tested on:** 19/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Col. (above 30 ft.) "C"(4000 Psi)	26	5	2025	6Diax12	---	14	28.28	62	4911	---	Non Engraved
2	Col. (above 30 ft.) "C"(4000 Psi)	26	5	2025	6Diax12	---	14	28.28	68	5386	---	Non Engraved
3	Col. (above 30 ft.) "C"(4000 Psi)	26	5	2025	6Diax12	---	14	28.28	72	5703	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9626
 Dr. Umbreen

To: Mr. Aftab Ahmad
 Chief Engineer, NESPAK (Pvt.) Ltd. Construction Management Division. (M/S Anjum Hafeez Construc
Project: Enhancement & Construction of the Shrine Syed Ali-Hajveri (R.A) Data Ganj Bakhsh, Lahore.
Our Ref. No. CL/CED/ 8636 **Dated:** 20/06/2025
Your Ref. No. 4580/13/AA/01/07 **Dated:** 29/01/2025

Test Specification
 (ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 17/06/2025 **Tested on:** 19/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	Pile No.7 "C" (4000 Psi)	22	1	2025	6Diax12	---	13.4	28.28	88	6970	---	Non Engraved
2	Pile No.7 "C" (4000 Psi)	22	1	2025	6Diax12	---	14	28.28	82	6495	---	Non Engraved
3	Pile No.7 "C" (4000 Psi)	22	1	2025	6Diax12	---	15	28.28	80	6337	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

9625
Dr. Umbreen

To: Mr. Muhammad Sulaman Basharat
Site Civil Engineer, AAA Partnership Pvt. Ltd.

Project: JDW Tower, Lahore.

Our Ref. No. CL/CED/ 8637

Dated: 20/06/2025

Test Specification

Your Ref. No. AAA/SO/MSB/117/2025

Dated: 17/06/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 17/06/2025 Tested on: 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(5000 Psi)	4	5	2025	6Diax12	---	13.2	28.28	63	4990	---	Non Engraved
2	(5000 Psi)	4	5	2025	6Diax12	---	13.2	28.28	80	6337	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9628
 Dr. Umbreen

To: Site Incharge
Eagle Construction & Co.

Project: PKD Eglo

Our Ref. No. CL/CED/ 8638

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: 18/06/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 18/06/2025 Tested on: 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(4000 Psi)	17	5	2025	6Diax12	---	13.6	28.28	66	5228	---	Non Engraved
2	(4000 Psi)	17	5	2025	6Diax12	---	13	28.28	42	3327	---	Non Engraved
3	(4000 Psi)	17	5	2025	6Diax12	---	13	28.28	34	2693	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Column - Grid 3 to 10 & G to D)

Our Ref. No. CL/CED/ 8639

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	26	3	2025	6Diax12	---	13.8	28.28	70	5545	---	Non Engraved
2	(6000 Psi)	26	3	2025	6Diax12	---	13.2	28.28	80	6337	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Column - Grid 3 to 10 & G to D)

Our Ref. No. CL/CED/ 8640

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	21	3	2025	6Diax12	---	14	28.28	74	5861	---	Non Engraved
2	(6000 Psi)	21	3	2025	6Diax12	---	13.8	28.28	80	6337	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Raft - Grid 3 to 10 & G to D)

Our Ref. No. CL/CED/ 8641

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 **in dry/wet condition**



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(4500 Psi)	8	3	2025	6Diax12	---	14	28.28	80	6337	---	Non Engraved
2	(4500 Psi)	8	3	2025	6Diax12	---	13.4	28.28	68	5386	---	Non Engraved
3	(4500 Psi)	8	3	2025	6Diax12	---	13	28.28	79	6257	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Column- Grid 3 to 10 & G to D)

Our Ref. No. CL/CED/ 8642

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	24	4	2025	6Diax12	---	14.4	28.28	80	6337	---	Non Engraved
2	(6000 Psi)	24	4	2025	6Diax12	---	14	28.28	80	6337	---	Non Engraved
3	(6000 Psi)	24	4	2025	6Diax12	---	13.6	28.28	60	4752	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Retaining Wall)

Our Ref. No. CL/CED/ 8643

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 Tested on: 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	24	4	2025	6Diax12	---	13.8	28.28	76	6020	---	Non Engraved
2	(6000 Psi)	24	4	2025	6Diax12	---	14	28.28	82	6495	---	Non Engraved
3	(6000 Psi)	24	4	2025	6Diax12	---	14	28.28	79	6257	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Retaining Wall)

Our Ref. No. CL/CED/ 8644

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 **in dry/wet condition**



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	26	3	2025	6Diax12	---	14	28.28	80	6337	---	Non Engraved
2	(6000 Psi)	26	3	2025	6Diax12	---	14	28.28	66	5228	---	Non Engraved
3	(6000 Psi)	26	3	2025	6Diax12	---	14	28.28	68	5386	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Retaining Wall)

Our Ref. No. CL/CED/ 8645

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	15	4	2025	6Diax12	---	14	28.28	60	4752	---	Non Engraved
2	(6000 Psi)	15	4	2025	6Diax12	---	13	28.28	60	4752	---	Non Engraved
3	(6000 Psi)	15	4	2025	6Diax12	---	13	28.28	82	6495	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Shear Wall W5)

Our Ref. No. CL/CED/ 8646

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 Tested on: 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	15	4	2025	6Diax12	---	14	28.28	70	5545	---	Non Engraved
2	(6000 Psi)	15	4	2025	6Diax12	---	14	28.28	74	5861	---	Non Engraved
3	(6000 Psi)	15	4	2025	6Diax12	---	13	28.28	68	5386	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. Raft (Grid 3 to 10 & G to D)

Our Ref. No. CL/CED/ 8647

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 **in dry/wet condition**



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(4500 Psi)	7	3	2025	6Diax12	---	13	28.28	72	5703	---	Non Engraved
2	(4500 Psi)	7	3	2025	6Diax12	---	13.2	28.28	66	5228	---	Non Engraved
3	(4500 Psi)	7	3	2025	6Diax12	---	13.2	28.28	84	6653	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9615
 Dr. Umbreen

To: Mr. Naeem Akhtar
 Director, Usman Ibrahim Construction Pakistan

Project: Construction of Alam Tower. (Second Basement Shear Wall W3)

Our Ref. No. CL/CED/ 8648

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 **in dry/wet condition**



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(6000 Psi)	28	4	2025	6Diax12	---	14	28.28	80	6337	---	Non Engraved
2	(6000 Psi)	28	4	2025	6Diax12	---	13.8	28.28	84	6653	---	Non Engraved
3	(6000 Psi)	28	4	2025	6Diax12	---	13	28.28	56	4436	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

9604
Dr. Umbreen

To: Mr. Sabeeh Farooq Khokhar
PAF, Falcon Complex, Gulberg III, Lahore.

Project: Nil

Our Ref. No. CL/CED/ 8649-1 of 2

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 13/06/2025 Tested on: 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	14	4	2025	6x6x6	---	7.8	36	70	4356	---	Non-Engraved
2	---	14	4	2025	6x6x6	---	7.8	36	56	3484	---	Non-Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

9604
Dr. Umbreen

To: Mr. Sabeeh Farooq Khokhar
PAF, Falcon Complex, Gulberg III, Lahore.

Project: Nil

Our Ref. No. CL/CED/ 8649-2 of 2

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 13/06/2025 Tested on: 20/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	14	4	2025	6Diax12	---	12.8	28.28	84	6653	---	Non Engraved
2	---	14	4	2025	6Diax12	---	13	28.28	64	5069	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9603
 Dr. Umbreen

To: Mr. Zeeshan Ibrahim
 Manager Administration, Lockersmith Limited.

Project: Nil

Our Ref. No. CL/CED/ 8650

Dated: 20/06/2025

Test Specification

Your Ref. No. LS-GLS-05-72

Dated: 11/06/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 13/06/2025 **Tested on:** 20/06/2025 **in dry/wet condition**



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	14	5	2025	6x6x6	---	7.2	36	64	3982	---	Non-Engraved
2	---	14	5	2025	6x6x6	---	7.8	36	92	5724	---	Non-Engraved
3	---	14	5	2025	6x6x6	---	8	36	96	5973	---	Non-Engraved
4	---	14	5	2025	6x6x6	---	7.8	36	56	3484	---	Non-Engraved
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9525
 Dr. Umbreen

To: Mr. Ali Ahmad
 Accounts Officer, M/s Mark Development (Pvt) Ltd. Lahore.

Project: Construction of Project " SOS Children's Village, Lahore."

Our Ref. No. CL/CED/ 8651

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: 27/05/2025

(----)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/05/2025 **Tested on:** 20/06/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	MS	---	---	---	8.8 x 4.1 x 3	3400	2790	36.08	36	2235	21.86	---
2	MS	---	---	---	8.9 x 4.2 x 3	3470	2860	37.38	37	2217	21.33	---
3	MS	---	---	---	8.9 x 4.2 x 3	3400	2790	37.38	39	2337	21.86	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9535
 Dr. Umbreen

To: Sub Divisional Officer
 Buildings Sub Division, Shakargarh.

Project: Establishment of Civil Veterinary Dispensary at Village Haryal Tehsil Shakargarh District Narowal.

Our Ref. No. CL/CED/ 8652

Dated: 20/06/2025

Test Specification

Your Ref. No. 2069/Sg

Dated: 03/03/2025

(----)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/05/2025 **Tested on:** 20/06/2025 **in dry/wet condition**

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Z-1	---	---	---	8.8 x 4.2 x 2.9	3690	3295	36.96	39	2364	11.99	---
2	Z-1	---	---	---	8.8 x 4.3 x 3	3720	3220	37.84	39	2309	15.53	---
3	Z-1	---	---	---	9 x 4.2 x 3	3780	3310	37.8	38	2252	14.2	---
4	Z-1	---	---	---	8.8 x 4.3 x 2.9	3565	3160	37.84	39	2309	12.82	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9596
 Dr. Umbreen

To: Engr. Zohaib Abbas
 Co-Ordinator: Projects, Ittefaq Construction Associates (Pvt) Ltd. (M/S Hike Engineering Consultants)
 Project: Construction of Diagnostic Center for Mr. Manzoor Ahmad Bhatti. Plot No.906 & 907 R-1, Johar Town Lahore.
 Our Ref. No. CL/CED/ 8453 Dated: 20/06/2025 Test Specification
 Your Ref. No. Nil Dated: 13/06/2025 (----)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **13/06/2025** Tested on: **20/06/2025** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	R7	---	---	---	9 x 4.3 x 3	---	3485	38.7	36	2084	---	---
2	R7	---	---	---	8.9 x 4.3 x 2.9	---	3635	38.27	35	2049	---	---
3	R7	---	---	---	9 x 4.3 x 3	---	3290	38.7	34	1968	---	---
4	Sword(S)	---	---	---	8.9 x 4.3 x 3	---	3320	38.27	38	2224	---	---
5	Sword(S)	---	---	---	9 x 4.3 x 3	---	3300	38.7	29	1679	---	---
6	Sword(S)	---	---	---	8.9 x 4.3 x 2.9	---	3260	38.27	33	1932	---	---
7	OR	---	---	---	9 x 4.3 x 2.9	---	3575	38.7	32	1852	---	---
8	OR	---	---	---	8.9 x 4.3 x 3	---	3560	38.27	36	2107	---	---
9	OR	---	---	---	8.9 x 4.3 x 3	---	3530	38.27	40	2341	---	---
10	R-2	---	---	---	8.8 x 4.3 x 3	---	3370	37.84	35	2072	---	---
11	R-2	---	---	---	9 x 4.3 x 3	---	3410	38.7	33	1910	---	---
12	R-2	---	---	---	8.9 x 4.2 x 3	---	3310	37.38	36	2157	---	---
13	A	---	---	---	8.9 x 4.2 x 3	---	3325	37.38	38	2277	---	---
14	A	---	---	---	8.9 x 4.2 x 2.9	---	3130	37.38	37	2217	---	---
15	A	---	---	---	8.9 x 4.2 x 2.9	---	3170	37.38	39	2337	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9602
 Dr. Umbreen

To: Radiant Construction Technologies LLP
 Mohafiz Town, Multan Road Lahore.

Project: Nil

Our Ref. No. CL/CED/ 8654

Dated: 20/06/2025

Test Specification

Your Ref. No. Nil

Dated: 13/06/2025

(---)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 13/06/2025 Tested on: 19/06/2025 in dry/wet condition



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	ConTile Bond R	22	5	2025	2x2x2	---	250	4	4.5	2520	---	Non Engraved
2	ConTile Bond R	22	5	2025	2x2x2	---	240	4	5.2	2912	---	Non Engraved
3	ConTile Bond R	22	5	2025	2x2x2	---	235	4	5	2800	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9608
 Dr. Umbreen

To: Precision Polymers (Pvt) Ltd.
 15 Km Multan Road Lahore.

Project: Nil

Our Ref. No. CL/CED/ 8655

Dated: 20/06/2025

Test Specification

Your Ref. No. PPPL/001/UET/2025

Dated: 16/06/2025

(----)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 16/06/2025 **Tested on:** 20/06/2025 **in dry/wet condition**



Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Heat Resistant Tuff Tile	---	---	---	8.0x4.0x1.1	---	1215	32	54	3780	---	---
2	---	---	---	---	---	---	---	---	---	---	---	---
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by: Nil

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory