



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

8997
 Dr. Aqsa

To: Mr. Sulman
 Material Manager, BH Consultants, Garden Town, Lahore.

Project: 4-Storey Commercial Building Construction (Frame Structure) E-1 Block, Valancia Society, Lahore.

Our Ref. No. CL/CED/ 7576

Dated: 04/03/2025

Test Specification

Your Ref. No. 024/025

Dated: 27/02/2025

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 27/02/2025 Tested on: 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	3000 Psi (1:2:4)	29	1	2025	6Diax12	---	14.4	28.28	75	5941	---	Non Engraved
2	3000 Psi (1:2:4)	29	1	2025	6Diax12	---	13.8	28.28	46	3644	---	Non Engraved
3	3000 Psi (1:2:4)	29	1	2025	6Diax12	---	14	28.28	53	4198	---	Non Engraved
4	4000 Psi (1:2:4)	14	2	2025	6Diax12	---	14	28.28	70	5545	---	Non Engraved
5	4000 Psi (1:2:4)	14	2	2025	6Diax12	---	14	28.28	68	5386	---	Non Engraved
6	4000 Psi (1:2:4)	14	2	2025	6Diax12	---	14.4	28.28	75	5941	---	Non Engraved
7	3000 Psi (1:1.2:3)	14	2	2025	6Diax12	---	14	28.28	77	6099	---	Non Engraved
8	3000 Psi (1:1.2:3)	14	2	2025	6Diax12	---	14.4	28.28	79	6257	---	Non Engraved
9	3000 Psi (1:1.2:3)	14	2	2025	6Diax12	---	14	28.28	75	5941	---	Non Engraved
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

8889
 Dr. Aqsa

To: Sub Divisional Officer
 Buildings Sub Division No. 6, Lahore

Project: Addition Alteration to Facilitation Center in Front Office in Punjab Civil Secretariat, Lahore.

Our Ref. No. CL/CED/ 7577

Dated: 04/03/2025

Test Specification

Your Ref. No. 882/Sd-6th

Dated: 31/01/2025

(BS 3921)**

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 12/02/2025 Tested on: 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	ZS	---	---	---	8.9 x 4.4 x 3	3755	3325	39.16	40	2288	12.93	---
2	ZS	---	---	---	8.9 x 4.5 x 2.9	3550	3200	40.05	42	2349	10.94	---
3	ZS	---	---	---	8.8 x 4.4 x 2.9	3660	3365	38.72	40	2314	8.77	---
4	ZS	---	---	---	9 x 4.4 x 3	3880	3460	39.6	42	2376	12.14	---
5	ZS	---	---	---	9 x 4.4 x 3	3820	3390	39.6	39	2206	12.68	---
6	ZS	---	---	---	9 x 4.4 x 2.9	3725	3315	39.6	41	2319	12.37	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9013
 Dr. Aqsa

To: Engr. M. Imran
 Resident Engineer, Master Consulting Engineers Pvt. Ltd.
Project: Construction of 07-Storey Residential Block Having Minimum 100 Rooms with Attached Bathroom Facilities at Gurdwara Janamasthan, Nankana Sahib.
Our Ref. No. CL/CED/ 7578 **Dated:** 04/03/2025 **Test Specification**
Your Ref. No. RE/NKB/RCC-45 **Dated:** 26/02/2025 **(BS 1881-116)**

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 28/2/2025 **Tested on:** 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Slab 4th Floor (1:1.5:3)	30	1	2025	6x6x6	---	9	36	85	5289	---	Engraved
2	Slab 4th Floor (1:1.5:3)	30	1	2025	6x6x6	---	9	36	90	5600	---	Engraved
3	Slab 4th Floor (1:1.5:3)	30	1	2025	6x6x6	---	9.2	36	108	6720	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

8995
 Dr. Aqsa

To: Mr. Ammad Hassan
 Civil Department, Nishat Mills Ltd. Dyeing & Finishing Plant Lahore.

Project: Construction of Compressor Room U-29, 22 Km Off Ferozepur Road, 5-km Nishat Avenue Lahore.

Our Ref. No. CL/CED/ 7579

Dated: 04/03/2025

Test Specification

Your Ref. No. Nil

Dated: 26/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 27/2/2025 **Tested on:** 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Plinth Beams 1~4/A~C, C-20	17	2	2025	6x6x6	---	8.2	36	46	2862	---	Non Engraved
2	Plinth Beams 1~4/A~C, C-20	17	2	2025	6x6x6	---	8.4	36	56	3484	---	Non Engraved
3	Plinth Beams 1~4/A~C, C-20	17	2	2025	6x6x6	---	8.4	36	50	3111	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

8999
 Dr. Aqsa

To: Mr. Arfan Nazir
 Manager Civil, Nishat Linen Pvt. Ltd.

Project: Construction of Fabric Godown Extension. 21 Km Ferozepur Road, Lahore.

Our Ref. No. CL/CED/ 7580

Dated: 04/03/2025

Test Specification

Your Ref. No. NL/CT/005

Dated: 27/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 27/2/2025 Tested on: 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	RCC Slab, C-24	19	1	2025	6x6x6	---	9	36	110	6844	---	Non Engraved
2	RCC Slab, C-24	19	1	2025	6x6x6	---	8.8	36	63	3920	---	Non Engraved
3	RCC Slab, C-24	19	1	2025	6x6x6	---	9	36	105	6533	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9009
 Dr. Aqsa

To: Assistant Resident Engineer
 16 City of Project, Package # I (Jhelum) MM Pakistan Pvt. Ltd.

Project: Construction of Storm Water Drainage Facilities in Jhelum (Walls)

Our Ref. No. CL/CED/ 7581

Dated: 04/03/2025

Test Specification

Your Ref. No. ARE/JHE-SWJ/MC-21

Dated: 28/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 28/2/2025 Tested on: 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(1:1.5:3)	18	1	2025	6x6x6	---	8.2	36	51	3173	---	Engraved
2	(1:1.5:3)	18	1	2025	6x6x6	---	8.2	36	49	3049	---	Engraved
3	(1:1.5:3)	18	1	2025	6x6x6	---	8.2	36	39	2427	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9009
 Dr. Aqsa

To: Assistant Resident Engineer,
 16 City of Project, Package # I (Jhelum) MM Pakistan Pvt. Ltd.

Project: Construction of Storm Water Drainage Facilities in Jhelum (Slab)

Our Ref. No. CL/CED/ 7582

Dated: 04/03/2025

Test Specification

Your Ref. No. ARE/JHE-SWJ/MC-20

Dated: 28/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 28/2/2025 **Tested on:** 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(1:1.5:3)	15	2	2025	6x6x6	---	8.2	36	41	2551	---	Engraved
2	(1:1.5:3)	15	2	2025	6x6x6	---	8.2	36	51	3173	---	Engraved
3	(1:1.5:3)	15	2	2025	6x6x6	---	8.2	36	48	2987	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

9009
 Dr. Aqsa

To: Assistant Resident Engineer,
 16 City of Project, Package # I (Jhelum) MM Pakistan Pvt. Ltd.

Project: Construction of Storm Water Drainage Facilities in Jhelum (Bed)

Our Ref. No. CL/CED/ 7583

Dated: 04/03/2025

Test Specification

Your Ref. No. ARE/JHE-SWJ/MC-22

Dated: 28/02/2025

(BS 1881-116)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 28/2/2025 **Tested on:** 04/03/2025 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	(1:1.5:3)	17	1	2025	6x6x6	---	8	36	34	2116	---	Engraved
2	(1:1.5:3)	17	1	2025	6x6x6	---	8.2	36	82	5102	---	Engraved
3	(1:1.5:3)	17	1	2025	6x6x6	---	8.2	36	85	5289	---	Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory