



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7084
Dr. Aqsa

To: Mr. Muhammad Yaseen
Sr Project Manager, Pakistan Engineering Solution, Lower Mall, Lahore.

Project: Construction of National Food Galaxy Project at Fidmic Sahianwala Faisalabad.

Our Ref. No. CL/CED/ 4812

Dated: 08/05/2024

Test Specification

Your Ref. No. PES-NFL-032

Dated: 25/4/2024

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	5	3	2024	6Diax12	---	14	28.28	48	3802	---	Non Engraved
2	---	5	3	2024	6Diax12	---	14	28.28	64	5069	---	Non Engraved
3	---	5	3	2024	6Diax12	---	13.6	28.28	58	4594	---	Non Engraved
4	---	25	3	2024	6Diax12	---	14	28.28	37	2931	---	Non Engraved
5	---	25	3	2024	6Diax12	---	14	28.28	70	5545	---	Non Engraved
6	---	25	3	2024	6Diax12	---	14	28.28	65	5149	---	Non Engraved
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7101
 Dr. M. Mazhar

To: Dr. Khalil Ahmad
 ADGHS / PD IRMNCH & NP, Program Manager PHCIP- P&SHD

Project: Punjab Human Capital Investment Project (PHCIP)

Our Ref. No. CL/CED/ 4813

Dated: 08/05/2024

Test Specification

Your Ref. No. PIU-H/PHCIP/PM/520/2024

Dated: 29/4/2024

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 Tested on: 07/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	4	4	2024	6Diax12	---	12.4	28.28	52	4119	---	Engraved
2	---	4	4	2024	6Diax12	---	13	28.28	54	4277	---	Engraved
3	---	4	4	2024	6Diax12	---	13	28.28	50	3960	---	Engraved
4	---	7	4	2024	6Diax12	---	12.4	28.28	54	4277	---	Engraved
5	---	7	4	2024	6Diax12	---	13	28.28	56	4436	---	Engraved
6	---	7	4	2024	6Diax12	---	12.8	28.28	38	3010	---	Engraved
7	---	24	4	2024	6Diax12	---	13.2	28.28	58	4594	---	Non Engraved
8	---	24	4	2024	6Diax12	---	12.8	28.28	54	4277	---	Non Engraved
9	---	24	4	2024	6Diax12	---	14	28.28	52	4119	---	Non Engraved
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7091
Dr. M. Mazhar

To: Mr. Shahid Iqbal
SHAHID IQBAL BUILDERS, Consultants, Architects, Contractors

Project: Construction of 101 DD Plaza Commerical Lahore. (First Floor Column, 1:1.5:3)

Our Ref. No. CL/CED/ 4814

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 Tested on: 07/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	(5000 Psi)	15	3	2024	6Diax12	---	14	28.28	44	3485	---	Non Engraved
2	(5000 Psi)	15	3	2024	6Diax12	---	13	28.28	24	1901	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7091
 Dr. M. Mazhar

To: Mr. Shahid Iqbal
 SHAHID IQBAL BUILDERS, Consultants, Architects, Contractors

Project: Construction of 101 DD Plaza Commerical Lahore. (First Floor Slab, 1:2:4)

Our Ref. No. CL/CED/ 4815

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 **Tested on:** 07/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	(4000 Psi)	19	3	2024	6Diax12	---	13.2	28.28	48	3802	---	Non Engraved
2	(4000 Psi)	19	3	2024	6Diax12	---	13.4	28.28	85	6733	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7091
Dr. M. Mazhar

To: Mr. Shahid Iqbal
SHAHID IQBAL BUILDERS, Consultants, Architects, Contractors

Project: Construction of 101 DD Plaza Commerical Lahore. (Second Floor Slab, 1:2:4)

Our Ref. No. CL/CED/ 4816

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 Tested on: 07/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	(4000 Psi)	7	4	2024	6Diax12	---	13	28.28	33	2614	---	Non Engraved
2	(4000 Psi)	7	4	2024	6Diax12	---	13.2	28.28	34	2693	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7091
Dr. M. Mazhar

To: Mr. Shahid Iqbal
SHAHID IQBAL BUILDERS, Consultants, Architects, Contractors

Project: Construction of 101 DD Plaza Commerical Lahore. (Mazzanine Floor Column, 1:1.5:3)

Our Ref. No. CL/CED/ 4817

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 Tested on: 07/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	(5000 Psi)	18	2	2024	6Diax12	---	13	28.28	61	4832	---	Non Engraved
2	(5000 Psi)	18	2	2024	6Diax12	---	13.2	28.28	50	3960	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7091
Dr. M. Mazhar

To: Mr. Shahid Iqbal
SHAHID IQBAL BUILDERS, Consultants, Architects, Contractors

Project: Construction of 101 DD Plaza Commerical Lahore. (Second Floor Column, 1:1.5:3)

Our Ref. No. CL/CED/ 4818

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 Tested on: 07/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	---	4	4	2024	6Diax12	---	12.8	28.28	58	4594	---	Non Engraved
2	---	4	4	2024	6Diax12	---	14	28.28	80	6337	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7091
Dr. M. Mazhar

To: Mr. Shahid Iqbal
SHAHID IQBAL BUILDERS, Consultants, Architects, Contractors

Project: Construction of 101 DD Plaza Commerical Lahore. (Mezzanine Floor Slab, 1:2:4)

Our Ref. No. CL/CED/ 4819

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 Tested on: 07/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	(4000 Psi)	21	2	2024	6Diax12	---	13.2	28.28	68	5386	---	Non Engraved
2	(4000 Psi)	21	2	2024	6Diax12	---	13.8	28.28	66	5228	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7118
Dr. Aqsa

To: **Project Manager**
Farrukh Nadeem, Innovative ® Construction Company

Project: Construction of Shoring Works at Kingdom Arena, RUDA Lahore.

Our Ref. No. CL/CED/ 4820

Dated: 08/05/2024

Test Specification

Your Ref. No. ICL/Ruda

Dated: 02/05/2024

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **02/05/2024** Tested on: **08/05/2024** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	---	30	3	2024	6Diax12	---	14	28.28	78	6178	---	Non Engraved
2	---	30	3	2024	6Diax12	---	14.2	28.28	83	6574	---	Non Engraved
3	---	30	3	2024	6Diax12	---	14	28.28	84	6653	---	Non Engraved
4	---	31	3	2024	6Diax12	---	13.4	28.28	72	5703	---	Non Engraved
5	---	31	3	2024	6Diax12	---	14.4	28.28	88	6970	---	Non Engraved
6	---	31	3	2024	6Diax12	---	13.8	28.28	93	7366	---	Non Engraved
7	---	1	4	2024	6Diax12	---	14.6	28.28	72	5703	---	Non Engraved
8	---	1	4	2024	6Diax12	---	14	28.28	63	4990	---	Non Engraved
9	---	1	4	2024	6Diax12	---	13.8	28.28	66	5228	---	Non Engraved
10	---	2	4	2024	6Diax12	---	14	28.28	38	3010	---	Non Engraved
11	---	2	4	2024	6Diax12	---	14.2	28.28	63	4990	---	Non Engraved
12	---	2	4	2024	6Diax12	---	13.8	28.28	68	5386	---	Non Engraved
13	---	3	4	2024	6Diax12	---	14.6	28.28	69	5465	---	Non Engraved
14	---	3	4	2024	6Diax12	---	14	28.28	68	5386	---	Non Engraved
15	---	3	4	2024	6Diax12	---	13.4	28.28	74	5861	---	Non Engraved
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7122
Dr. Aqsa

To: Mr. Syed Usman Ali
AIR HEIGHTS DEVELOPERS (Pvt) Ltd.

Project: DE VIEW located at 72-Attaturk Block New Garden Town Lahore.

Our Ref. No. CL/CED/ 4821

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 29/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Basement Slab	29	3	2024	6Diax12	---	14.2	28.28	36	2851	---	Non Engraved
2	Basement Slab	29	3	2024	6Diax12	---	13.6	28.28	37	2931	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7078
Dr. Aqsa

To: **Managing Partner**
Shaheen Associates, New Garden Town Lahore

Project: Escorts Advanced Textiles (Pvt) Ltd Muridkey - Extension of Spinning Unit (Ground Floor)

Our Ref. No. CL/CED/ 4822

Dated: 08/05/2024

Test Specification

Your Ref. No. SBA-1/5050

Dated: 26/4/2024

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **26/4/2024** Tested on: **08/05/2024** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Slab Grid D-F(Line 24-26) (1:2:4)	1	4	2024	6Diax12	---	14	28.28	62	4911	---	Engraved
2	Slab Grid D-F(Line 24-26) (1:2:4)	1	4	2024	6Diax12	---	14.4	28.28	41	3248	---	Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7095
 Dr. Aqsa

To: Engr Ahmed
 Manager Structures, M/S Iqbal, Uzair and Associates, Johar Town Lahore

Project: Site 181-D, Model Town Lahore. (Retaining Wall, 3000 Psi)

Our Ref. No. CL/CED/ 4823

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 **Tested on:** 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Mix Design Ratio (1:1.8:3.6)	15	3	2024	6Diax12	---	14.2	28.28	49	3881	---	Non Engraved
2	Mix Design Ratio (1:1.8:3.6)	15	3	2024	6Diax12	---	14.2	28.28	52	4119	---	Non Engraved
3	Mix Design Ratio (1:1.8:3.6)	15	3	2024	6Diax12	---	14	28.28	45	3564	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7095
Dr. Aqsa

To: Engr Ahmed
Manager Structures, M/S Iqbal, Uzair and Associates, Johar Town Lahore

Project: Site 181-D, Model Town Lahore. (Foundation Bed, 3000 Psi)

Our Ref. No. CL/CED/ 4824

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Mix Design Ratio (1:1.8:3.6)	18	2	2024	6Diax12	---	13	28.28	36	2851	---	Non Engraved
2	Mix Design Ratio (1:1.8:3.6)	18	2	2024	6Diax12	---	13	28.28	34	2693	---	Non Engraved
3	Mix Design Ratio (1:1.8:3.6)	18	2	2024	6Diax12	---	13.4	28.28	38	3010	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7095
 Dr. Aqsa

To: Engr Ahmed
 Manager Structures, M/S Iqbal, Uzair and Associates, Johar Town Lahore

Project: Site Jewel One, 97A Gulberg 3, Lahore. Slabs of Second Floor (First Floor Slab), 3000 Psi)

Our Ref. No. CL/CED/ 4825

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 **Tested on:** 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Mix Design Ratio (1:1.8:3.6)	26	3	2024	6Diax12	---	13.4	28.28	55	4356	---	Non Engraved
2	Mix Design Ratio (1:1.8:3.6)	26	3	2024	6Diax12	---	14.2	28.28	57	4515	---	Non Engraved
3	Mix Design Ratio (1:1.8:3.6)	26	3	2024	6Diax12	---	14	28.28	61	4832	---	Non Engraved
4	Mix Design Ratio (1:1.8:3.6)	26	3	2024	6Diax12	---	14.4	28.28	50	3960	---	Non Engraved
5	Mix Design Ratio (1:1.8:3.6)	26	3	2024	6Diax12	---	14.2	28.28	69	5465	---	Non Engraved
6	Mix Design Ratio (1:1.8:3.6)	26	3	2024	6Diax12	---	13.4	28.28	68	5386	---	Non Engraved
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7095
 Dr. Aqsa

To: Engr Ahmed
 Manager Structures, M/S Iqbal, Uzair and Associates, Johar Town Lahore

Project: Site 36 Indus, Green Forts, Lahore. (Slabs and Canopies)

Our Ref. No. CL/CED/ 4826

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 **Tested on:** 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Mix Design Ratio (1:2:4)	13	3	2024	6Diax12	---	13.2	28.28	52	4119	---	Non Engraved
2	Mix Design Ratio (1:2:4)	13	3	2024	6Diax12	---	14	28.28	34	2693	---	Non Engraved
3	Mix Design Ratio (1:2:4)	13	3	2024	6Diax12	---	14	28.28	45	3564	---	Non Engraved
4	Mix Design Ratio (1:2:4)	13	3	2024	6Diax12	---	14	28.28	68	5386	---	Non Engraved
5	Mix Design Ratio (1:2:4)	13	3	2024	6Diax12	---	13.6	28.28	63	4990	---	Non Engraved
6	Mix Design Ratio (1:2:4)	13	3	2024	6Diax12	---	14	28.28	58	4594	---	Non Engraved
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7095
 Dr. Aqsa

To: Engr Ahmed
 Manager Structures, M/S Iqbal, Uzair and Associates, Johar Town Lahore

Project: Site 75-U Phase 7, DHA Lahore. (Foundation Bed, 3000 Psi)

Our Ref. No. CL/CED/ 4827

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 **Tested on:** 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Mix Design Ratio (1:2:4)	22	3	2024	6Diax12	---	14.2	28.28	42	3327	---	Non Engraved
2	Mix Design Ratio (1:2:4)	22	3	2024	6Diax12	---	15	28.28	54	4277	---	Non Engraved
3	Mix Design Ratio (1:2:4)	22	3	2024	6Diax12	---	14.6	28.28	51	4040	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7095
 Dr. Aqsa

To: Engr Ahmed
 Manager Structures, M/S Iqbal, Uzair and Associates, Johar Town Lahore

Project: Site 75-U Phase 7, DHA Lahore. (Retaining Walls, 3000 Psi)

Our Ref. No. CL/CED/ 4828

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: Nil

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 **Tested on:** 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Mix Design Ratio (1:2:4)	4	4	2024	6Diax12	---	14.6	28.28	53	4198	---	Non Engraved
2	Mix Design Ratio (1:2:4)	4	4	2024	6Diax12	---	15	28.28	56	4436	---	Non Engraved
3	Mix Design Ratio (1:2:4)	4	4	2024	6Diax12	---	14.6	28.28	46	3644	---	Non Engraved
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7094
Dr. Aqsa

To: Mr. Sufiyan Ali
Vice Nazim, Jamia-tul-Rasheed, Lahore Campus

Project: Construction of Jamia-Tur-Rasheed Lahore

Our Ref. No. CL/CED/ 4829

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: 30/4/2024

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	F-2 + F-2	27	3	2024	6Diax12	---	13.4	28.28	36	2851	---	Engraved
2	F-2 + F-2	27	3	2024	6Diax12	---	14	28.28	37	2931	---	Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7094
Dr. Aqsa

To: Mr. Sufiyan Ali
Vice Nazim, Jamia-tul-Rasheed, Lahore Campus

Project: Construction of Jamia-Tur-Rasheed Lahore Campus

Our Ref. No. CL/CED/ 4830

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: 30/4/2024

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	F-4 + F-4	26	3	2024	6Diax12	---	14.4	28.28	43	3406	---	Engraved
2	F-4 + F-4	26	3	2024	6Diax12	---	14	28.28	30	2376	---	Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** AC1318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7094
Dr. Aqsa

To: Mr. Sufiyan Ali
Vice Nazim, Jamia-tul-Rasheed, Lahore Campus

Project: Construction of Jamia-Tur-Rasheed Lahore Campus

Our Ref. No. CL/CED/ 4831

Dated: 08/05/2024

Test Specification

Your Ref. No. Nil

Dated: 30/4/2024

(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	F-9 + F-9	25	3	2024	6Diax12	---	14	28.28	25	1980	---	Engraved
2	F-9 + F-9	25	3	2024	6Diax12	---	14	28.28	35	2772	---	Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7100
Dr. Aqsa

To: Sub Divisional Officer
Maintenance Sub Division No. II, GOR-III Lahore
Project: Construction of One Multistorey Building for Residences Grade 11-14 (36 Nos) for Staff Colony at Chauburgi, Garden State, Multan Road, Lahore.
Our Ref. No. CL/CED/ 4832 Dated: 08/05/2024 Test Specification
Your Ref. No. 342 Sd/GOR-III, Lhr Dated: 15/3/2024 (ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	GF Columns (1:1.5:3)	15	3	2024	6Diax12	---	14	28.28	89	7050	---	Non Engraved
2	GF Columns (1:1.5:3)	15	3	2024	6Diax12	---	14	28.28	67	5307	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
University of Engineering and Technology, Lahore, Pakistan
Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
A carbon copy for the report has been retained in the lab for record.

7100
Dr. Aqsa

To: Sub Divisional Officer
Maintenance Sub Division No. II, GOR-III Lahore
Project: Construction of One Multistorey Building for Residences Grade 11-14 (36 Nos) for Staff Colony at Chauburgi, Garden State, Multan Road, Lahore
Our Ref. No. CL/CED/ 4833 Dated: 08/05/2024
Your Ref. No. 379 Sd/GOR-III, Lhr Dated: 15/3/2024

Test Specification
(ASTM C39)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: 30/4/2024 Tested on: 08/05/2024 in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorption (%)	Remarks
		DD	MM	YYYY								
1	Ground Floor Slab Conc. (1:2:4)	15	3	2024	6Diax12	---	14	28.28	81	6416	---	Non Engraved
2	Ground Floor Slab Conc. (1:2:4)	15	3	2024	6Diax12	---	13.4	28.28	49	3881	---	Non Engraved
3	---	---	---	---	---	---	---	---	---	---	---	---
4	---	---	---	---	---	---	---	---	---	---	---	---
5	---	---	---	---	---	---	---	---	---	---	---	---
6	---	---	---	---	---	---	---	---	---	---	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory



Plain and Reinforced Concrete Laboratory
Civil Engineering Department
 University of Engineering and Technology, Lahore, Pakistan
 Landline: 042-99029245 & 042-99029202 Mobile: 0307-0496895

ORIGINAL
 A carbon copy for the report has been retained in the lab for record.

7106
 Dr. Umbreen

To: Mr. Rashid Kamran
 Resident Engineer, Construction Management Division, NESPAK (Pvt) Ltd
 Project: Construction of Walkways and Traffic Regulatory Devices on 150 feet Wide Main Roads (S1, S2 & S3) & 80, 100 & 120 feet Wide Main Roads of LDA Avenue-I Scheme, Lahore.
 Our Ref. No. CL/CED/ 4834 Dated: 08/05/2024 Test Specification
 Your Ref. No. 2599/13/05/RK/WKW/155 Dated: 25/3/2024 (----)

COMPRESSION TEST REPORT



Concrete Cubes/Concrete Cylinders/Bricks/Cores/Tuff Tiles/Pavers

Specimens received on: **30/4/2024** Tested on: **07/05/2024** in dry/wet condition

Sr. No.	Mark*	Casting Date*			Size (in)	Wet Weight (Kg/ gms)	Dry Weight (Kg/ gms)	Area of X-Section (Sq. in)	Ultimate load (Imp.Tons)	Ultimate Stress (psi)	Water Absorpti on (%)	Remarks
		DD	MM	YYYY								
1	Rectangular, Grey, 60mm	---	---	---	7.8 x 3.8 x 2.4	---	2560	29.64	62	4686	---	---
2	Rectangular, Grey, 60mm	---	---	---	7.8 x 3.8 x 2.4	---	2880	29.64	107	8086	---	---
3	Rectangular, Grey, 60mm	---	---	---	7.8 x 3.8 x 2.4	---	2845	29.64	160	12092	---	---
4	Rectangular, Red, 60mm	---	---	---	7.8 x 3.8 x 2.4	---	2895	29.64	105	7935	---	---
5	Rectangular, Red, 60mm	---	---	---	7.8 x 3.8 x 2.4	---	2755	29.64	114	8615	---	---
6	Rectangular, Red, 60mm	---	---	---	7.8 x 3.8 x 2.4	---	2775	29.64	113	8540	---	---
7	---	---	---	---	---	---	---	---	---	---	---	---
8	---	---	---	---	---	---	---	---	---	---	---	---
9	---	---	---	---	---	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---	---	---	---	---	---
11	---	---	---	---	---	---	---	---	---	---	---	---
12	---	---	---	---	---	---	---	---	---	---	---	---
13	---	---	---	---	---	---	---	---	---	---	---	---
14	---	---	---	---	---	---	---	---	---	---	---	---
15	---	---	---	---	---	---	---	---	---	---	---	---
16	---	---	---	---	---	---	---	---	---	---	---	---

Witnessed by:

Results can also be seen on website <https://civil.uet.edu.pk/concrete-laboratory-reports1/>

- * as engraved on the specimens (if any)
- ** BS3921 requires average of ten clay brick samples for crushing strength and water absorption
- *** BS5328 requires mean of two cube sample strength at 28 days as characteristic strength
- **** ACI318-08 requires mean of two sample (6"diax12" cylinder) strength at 28 days as compressive strength

Note: Above results pertain to the unsealed samples supplied to the laboratory

- The laboratory is not responsible for sampling, originality and construction conditions (such as mix proportion, w/c ratio, compaction, curing and quality of ingredients)
- The test results are recommended to be interpreted in the light of above factors by the engineer.

Supervisor (Lab)

Director/Dy. Director Concrete Laboratory