Department of Civil Engineering (CED)

## **UNIVERSITY OF ENGINEERING & TECHNOLOGY (UET)**

LAHORE - 54890 (PAKISTAN)





Date:----

Mr. Rashid Kamran Resident Engineer, NESPAK,

Ref.----

Lahore.

Subject: <u>Testing of Coarse and Fine Aggregates</u>

Construction of Electric Bus Depot at Green Town, Lahore

Source: Sargodha Aggregate and Lawrencepur Sand

Dear Sir,

It is with reference to your letter No. 4792/13/RK/05/11 dated 19-12-2024.

Please find below the results for the tests conducted on the aggregate samples provided to this laboratory on 06-01-2025 through your representative.

## **Coarse Aggregate**

1. Sieve Analysis (ASTM C-136)

Sieve Size	1"	3/4"	1/2"	3/8"	#4
%age Passing	100	88.06	36.27	11.22	0

## 2. Sodium Sulphate Soundness (ASTM C-88)

Sieve Size	Weight of	Weight of	Percentage	Weighted
	Fraction	Fraction	Passing	Percentage
	Before Test.	After Test.	Designated Sieve	Loss.
1/2" + 3/8"	(gm)	(gm)	After Test.	
/2 /8	1002.4	993.1	0.93	0.72
			Total = 0.72%	

## 3. Los Angeles Abrasion Value Test (ASTM C-131/535)

<b>Grading Used</b>	<b>Los Angeles Abrasion Value</b>
_	(%)
В	15.80

### 4. Flakiness & Elongation Index (BS 812: Part 105)

Sieve Size		Individual	Weighted	Individual	Weighted	
Passing Retained		Flakiness Flakiness		Elongation	Elongation	
(in.)	(in.)	Index (%)	Index (%)	Index (%)	Index (%)	
1	3/4	8.94	1.07	14.26	1.70	
3/4	1/2	9.31	4.82	12.47	6.46	
1/2	3/8	8.35	2.09	12.99	3.25	
3/8	1/4	6.51	0.73	18.02	2.02	
		Flakiness Inc	dex = 8.71%	Elongation Ind	ex = 13.43%	

## 5. Clay Lumps and Friable Particles (ASTM C-142)

Clay Lumps and Friable Particles (%)
--------------------------------------

## **Fine Aggregate**

### 1. Sieve Analysis (ASTM C-136)

Sieve Size	1/2"	3/8"	#4	#8	#16	#30	#50	#100	#200
%age Passing	100	98.99	95.68	90.35	79.69	63.34	26.83	5.39	1.03

## 2. Fineness Modulus (ASTM C-142)

Fineness Modulus (	%)		2.40

## 3. Clay Lumps and Friable Particles (ASTM C-142)

Clay Lur	mps and Friable P	articles (%)	0.74

## 4. Sodium Sulphate Soundness (ASTM C-88)

	Sieve Size	Weight of	Weight of	Percentage	Weighted	
		Fraction	Fraction	Passing	Percentage	
4		Before Test	After Test	Designated Sieve	Loss	
		(gm)	(gm)	After Test		
	#4 to #8	100	98.8	1.20	0.06	
	#8 to #16	100	98.1	1.90	0.20	
	#16 to #30	100	98.7	1.30	0.21	
	#30 to #50	100	98.7	1.30	0.48	
	Total = 0.95%					

If you have further query, please do not hesitate to contact the undersigned.

Best Regards,

### Director

Transportation Engineering Laboratory

### Note:

- 1. This test report is based solely on the particular sample(s) supplied by the client and should not be reproduced in parts.
- 2. Sampling has not been performed by Transportation Engineering Laboratory (TEL), UET and TEL-UET does not accept the responsibility that the sample(s) supplied is/are truly representative sample(s) of any batch or stock or entire project.
- 3. While TEL-UET agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability thereof beyond the amount of the fee charged for the analysis or test.
- 4. The party shall assume full responsibility for the ethical use of the results in the test reports and the TEL-UET shall be held free from any and all claims which may result from the use of such data by client or others.
- 5. This test report shall not be reproduced wholly or in parts unless negotiated.

Department of Civil Engineering (CED)

## **UNIVERSITY OF ENGINEERING & TECHNOLOGY (UET)**

LAHORE - 54890 (PAKISTAN)





Mr. Mohammad Iqbal Project Manager,

Ref.----

BARQAAB Consulting Services (Pvt.) Limited.

**Subject:** Testing of Coarse and Fine Aggregates

Project: ADB-300C-R-2020: Design, Manufacturing, Supply, Installation, Testing and

Commissioning of 220 kV Jauharabad Grid Station

Dear Sir,

It is with reference to your letter No. BQB/220kV/GS/JHR/292 dated 28-02-2025.

Please find below the results for the tests conducted on the aggregate samples provided to this laboratory on 04-03-2025 through your representative.

## **Coarse Aggregate**

## Specific Gravity & Water Absorption (ASTM C-127)

Specific Gravity (oven dried condition)	2.62
Specific Gravity (saturated surface dry condition)	2.64
Apparent Specific Gravity	2.69
Water Absorption (%)	1.00

## Fine Aggregate

## **Specific Gravity & Water Absorption (ASTM C-128)**

Specific Gravity (OD)	2.57
Specific Gravity (SSD)	2.61
Apparent Specific Gravity	2.67
Water Absorption (%)	1.58

If you have further query, please do not hesitate to contact the undersigned.

Best Regards,

### Note:

- 1. This test report is based solely on the particular sample(s) supplied by the client and should not be reproduced in parts.
- 2. Sampling has not been performed by Transportation Engineering Laboratory (TEL), UET and TEL-UET does not accept the responsibility that the sample(s) supplied is/are truly representative sample(s) of any batch or stock or entire project.
- 3. While TEL-UET agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability thereof beyond the amount of the fee charged for the analysis or test.
- 4. The party shall assume full responsibility for the ethical use of the results in the test reports and the TEL-UET shall be held free from any and all claims which may result from the use of such data by client or others.
- 5. This test report shall not be reproduced wholly or in parts unless negotiated.

### Director

Department of Civil Engineering (CED)

## **UNIVERSITY OF ENGINEERING & TECHNOLOGY (UET)**

LAHORE - 54890 (PAKISTAN)



Engr. Muhammad Farooq Memon Resident Engineer, Metroplan-Asian JV, Site Office, NSIC - Sargodha.

Subject: Testing of Bitumen – AASHTO Standard (M-20)

Establishment of Nawaz Sharif Institute of Cardiology, Sargodha Project:

Source: **NRL** 

Dear Sir,

It is with reference to your letter No. Metroplan-Asian-JV/IDAP-NSIC-LAB/MB-SGD-RE/217 dated 03-03-2025.

Please find below the results of tests conducted on the bitumen sample provided to this laboratory through your representative.

Sr.#	Laboratory Tests	Results
1	Penetration (ASTM D-5)	69 Units
2	Penetration of Residue (ASTM D-5)	61 Units
3	Ductility (ASTM D-113)	Above 100 cm
4	Ductility of Residue (ASTM D-113)	Above 100 cm
5	Softening Point (ASTM D-36)	49.0°C
6	Flash Point (ASTM D-92)	290°C
7	Fire Point (ASTM D-92)	321°C
8	Solubility (ASTM D-2042)	99.80%
9	Specific Gravity Value (ASTM D-70)	1.021
10	Loss on Heating Value (ASTM D-6)	0.274%

If you have further query, please do not hesitate to contact the undersigned.

Best Regards,

- 1. This test report is based solely on the particular sample(s) supplied by the client and should not be reproduced in parts.
- 2. Sampling has not been performed by Transportation Engineering Laboratory (TEL), UET and TEL-UET does not accept the responsibility that the sample(s) supplied is/are truly representative sample(s) of any batch or stock or entire project.
- 3. While TEL-UET agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability thereof beyond the amount of the fee charged for the analysis or test.
- 4. The party shall assume full responsibility for the ethical use of the results in the test reports and the TEL-UET shall be held free from any and all claims which may result from the use of such data by client or others.
- 5. This test report shall not be reproduced wholly or in parts unless negotiated.

Director

Department of Civil Engineering (CED)

## **UNIVERSITY OF ENGINEERING & TECHNOLOGY (UET)**

LAHORE - 54890 (PAKISTAN)





Date:----

The Sub Divisional Officer, Highway Sub Division, Bhera.

Ref.----

Subject: Testing of Bituminous Asphaltic Cores (AWC)

Special Repair of Road from Bhera Malikwal Road at Awanwala to Huzarpur via Chak Sab Khan, Length = 9.00 km in District Sargodha

Dear Sir,

It is with reference to your letter No. 71Bhr dated 07-03-2025.

Please find below the results for the tests conducted on the three cores of asphalt wearing course provided to this laboratory on 19-03-2025 through your representative.

## BULK SPECIFIC GRAVITY OF COMPACTED ASPHALT (ASTM D2726):

Core #	Mean Thickness (cm)	Mean Diameter (cm)	Bulk Specific Gravity
11	7.710	10.000	2.215
12	8.520	10.000	2.258
23	5.883	10.000	2.245

If you have further query, please do not hesitate to contact the undersigned.

Best Regards,

### Note

- 1. This test report is based solely on the particular sample(s) supplied by the client and should not be reproduced in parts.
- 2. Sampling has not been performed by Transportation Engineering Laboratory (TEL), UET and TEL-UET does not accept the responsibility that the sample(s) supplied is/are truly representative sample(s) of any batch or stock or entire project.
- 3. While TEL-UET agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability thereof beyond the amount of the fee charged for the analysis or test.
- 4. The party shall assume full responsibility for the ethical use of the results in the test reports and the TEL-UET shall be held free from any and all claims which may result from the use of such data by client or others.
- 5. This test report shall not be reproduced wholly or in parts unless negotiated.

### Director

Department of Civil Engineering (CED)

## **UNIVERSITY OF ENGINEERING & TECHNOLOGY (UET)**

LAHORE - 54890 (PAKISTAN)





Date:----

Mr. Karar Abbas Sr. Assistant Manager, Department of Procurement, Pioneer Cement.

Ref.----

Subject: Testing of Coarse and Fine Aggregates

Dear Sir,

It is with reference to your letter No. PCL/PL04/UET/S&C/1151 dated 19-03-2025. Please find below the results for the tests conducted on the aggregate samples provided to this laboratory through your representative.

## **Coarse Aggregate**

1. Sieve Analysis (ASTM C-136)

Sieve Size	3/4"	1/2"	3/8"	#4
%age Passing	100	83.73	32.55	7.39

## 2. Specific Gravity & Water Absorption (ASTM C-127)

Specific Gravity (oven dried condition)	2.86
Specific Gravity (saturated surface dry condition)	2.87
Apparent Specific Gravity	2.89
Water Absorption (%)	0.31

## 3. Sodium Sulphate Soundness (ASTM C-88)

Sieve Size	Weight of	Weight of	Percentage	Weighted
	Fraction	Fraction	Passing	Percentage
	Before Test.	After Test.	Designated Sieve	Loss.
1/2" + 3/8"	(gm)	(gm)	After Test.	
/2 /8	1002.4	994.5	0.79	0.60
			Total = 0.60%	

### 4. Los Angeles Abrasion Value Test (ASTM C-131/535)

Grading Used	Los Angeles Abrasion Value
	(%)
В	15.50

## **Fine Aggregate**

## 1. Sieve Analysis (ASTM C-136)

Sieve Size	1/2"	3/8"	#4	#8	#16	#30	#50	#100	#200
%age Passing	100	91.18	82.74	67.63	51.56	37.28	17.46	3.71	1.73

### 2. Fineness Modulus (ASTM C-142)

## 3. Specific Gravity & Water Absorption (ASTM C-128)

Specific Gravity (OD)	2.69
Specific Gravity (SSD)	2.71
Apparent Specific Gravity	2.75
Water Absorption (%)	0.83

If you have further query, please do not hesitate to contact the undersigned.

Best Regards,

Director


Transportation Engineering Laboratory

### Note:

- 1. This test report is based solely on the particular sample(s) supplied by the client and should not be reproduced in parts.
- 2. Sampling has not been performed by Transportation Engineering Laboratory (TEL), UET and TEL-UET does not accept the responsibility that the sample(s) supplied is/are truly representative sample(s) of any batch or stock or entire project.
- 3. While TEL-UET agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability thereof beyond the amount of the fee charged for the analysis or test.
- 4. The party shall assume full responsibility for the ethical use of the results in the test reports and the TEL-UET shall be held free from any and all claims which may result from the use of such data by client or others.
- 5. This test report shall not be reproduced wholly or in parts unless negotiated.

Department of Civil Engineering (CED)

## **UNIVERSITY OF ENGINEERING & TECHNOLOGY (UET)**



The Resident Engineer, ESS-I-AAR Consultants, Sargodha.

Ref.----

Subject: <u>Testing of Bitumen – AASHTO Standard (M-20)</u>

Rehabilitation of Lillah Kandwal-Katha Saghral Tehsil P. D Khan (Phase-II)

District Jhelum & Khushab, Length = 20.53 km in District Khushab

Dear Sir,

It is with reference to your letter No. 517 dated 02-03-2025.

Please find below the results of tests conducted on the bitumen sample provided to this laboratory on 27-03-2025 through your representative.

Sr.#	Laboratory Tests	Results
1	Penetration (ASTM D-5)	67 Units
2	Ductility (ASTM D-113)	Above 100 cm
3	Softening Point (ASTM D-36)	49.1°C
4	Flash Point (ASTM D-92)	298°C
5	Fire Point (ASTM D-92)	336°C
6	Solubility (ASTM D-2042)	99.80%
7	Specific Gravity Value (ASTM D-70)	1.021
8	Loss on Heating Value (ASTM D-6)	0.238%

If you have further query, please do not hesitate to contact the undersigned.

Best Regards,

### Note:

1. This test report is based solely on the particular sample(s) supplied by the client and should not be reproduced in parts.

Date:----

- 2. Sampling has not been performed by Transportation Engineering Laboratory (TEL), UET and TEL-UET does not accept the responsibility that the sample(s) supplied is/are truly representative sample(s) of any batch or stock or entire project.
- 3. While TEL-UET agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability thereof beyond the amount of the fee charged for the analysis or test.
- 4. The party shall assume full responsibility for the ethical use of the results in the test reports and the TEL-UET shall be held free from any and all claims which may result from the use of such data by client or others.
- 5. This test report shall not be reproduced wholly or in parts unless negotiated.

## Director