

Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan, Ph: 92-42-99029202

To, Sub Divisional Officer Buildings Sub Division No. 22 Lahore

(Construction of Population Welfare House Punjab, at Lahore)

Reference # CED/TFL **2133** (Dr. M Rizwan Riaz)

Reference of the request letter # 172/22nd

Dated: 17-10-2022

Dated: 03-10-2022

Tension Test Report (Page -1/4)

Date of Test 18-10-2022 Gauge length 8 inches

Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Sr. No.	Weight	Diameter/ Size (inch)		Area (in²)		Yield load	Breaking Load	Breaking Load (isq) (isq)				Elongation	% Elongation	Remarks
S 2	(lbs/ft)	Nominal	Actual	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Nominal	Actual	(inch)		R
1	0.353	3/8	0.364	0.11	0.104	2700	4000	54100	57280	80200	84900	1.40	17.5	
2	0.353	3/8	0.364	0.11	0.104	2700	4000	54100	57290	80200	84900	1.30	16.3	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Note: only two samples for tensile and one sample for bend test													
	Bend Test													
3/8	" Dia Ba	ır Bend	Test Th	nrough	180° is \$	Satisfacto	ry							

I/C Testing Laboratoires UET Lahore, Pakistan.

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To, Sub Divisional Officer Buildings Sub Division No. 15 Lahore

(Construction of Court Rooms for Judicial Officers at Model Town, Lahore Group No. 1)

Reference # CED/TFL <u>2133 (Dr. M Rizwan Riaz)</u>

Reference of the request letter # 2185

Dated: 17-10-2022

Dated: 11-10-2022

Tension Test Report (Page -2/4)

Date of Test 18-10-2022 Gauge length 8 inches

Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Sr. No.	Weight	Diameter/ Size (inch)		Area (in²)		Yield load	Breaking Load	Yield Stress (psi)		Ultimate Stress (psi)		Elongation	% Elongation	Remarks
S	(lbs/ft)	Nominal	Actual	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Actual Nominal Actual		(inch)	I %	R
1	0.354	3/8	0.364	0.11	0.104	2700	4000	54100	57240	80200	84800	1.50	18.8	
2	0.356	3/8	0.365	0.11	0.105	2700	4000	54100	56840	80200	84200	1.40	17.5	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Note: only two samples for tensile and one sample for bend test													
	Bend Test													
3/8	3/8" Dia Bar Bend Test Through 180° is Satisfactory													

I/C Testing Laboratoires UET Lahore, Pakistan.

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan, Ph: 92-42-99029202

To, Sub Divisional Officer Buildings Sub Division No. 15 Lahore (Forest Complex at Ravi Road, Lahore)

Reference # CED/TFL **2133** (Dr. M Rizwan Riaz)

Reference of the request letter # 2184

Dated: 17-10-2022

Tension Test Report (Page -3/4)

Date of Test 18-10-2022 Gauge length 8 inches

Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Sr. No.	Diameter/ Size (inch)		Area (in²)		Yield load	Breaking Load	Yield Stress (psi)		Ultimate Stress (psi)		Elongation	% Elongation	Remarks	
S	(lbs/ft)	Nominal	Actual	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Nominal	Actual	(inch)	3 %	R
1	0.357	3/8	0.365	0.11	0.105	2700	4000	54100	56750	80200	84100	1.40	17.5	
2	0.355	3/8	0.364	0.11	0.104	2700	4000	54100	57090	80200	84600	1.30	16.3	
-	-	-	_	-	-	-	-	-	-	-	-	_	-	
-	-	-	_	-	-	-	-	-	-	-	-	_	-	
-	-	-	-	-	-	-	_	-	-	-	-	-	-	
-	-	-	-	-	-	-	_	-	-	-	-	-	-	
	Note: only two samples for tensile and one sample for bend test													
2 /2	Bend Test													
3/8	3/8" Dia Bar Bend Test Through 180° is Satisfactory													

I/C Testing Laboratoires UET Lahore, Pakistan.

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To, Sub Divisional Officer Buildings Sub Division No. 05 Lahore

(Extension / Expansion of Inspectorate of Prisons Punjab Lahore Group No. 1)

Reference # CED/TFL **2133** (Dr. M Rizwan Riaz)

Reference of the request letter # 2103/5th

Dated: 17-10-2022

Tension Test Report (Page -4/4)

Date of Test 18-10-2022 Gauge length 8 inches

Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Sr. No.	Weight	Diameter/ Size (inch)		Area (in²)		Yield load	Breaking Load	Yield Stress (psi)			te Stress si)	Elongation	% Elongation	Remarks
S	(lbs/ft)	Nominal	Actual	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Nominal	Actual	(inch)	% E	Re
1	0.355	3/8	0.364	0.11	0.104	2700	4000	54100	57100	80200	84600	1.50	18.8	
2	0.355	3/8	0.364	0.11	0.104	2700	3900	54100	57090	78200	82500	1.30	16.3	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	1	-	
			N	ote: on	ly two s	amples f	or tensile	and one	sample f	or bend	test			1
2/0	Bend Test 3/8" Dia Bar Bend Test Through 180° is Satisfactory													

I/C Testing Laboratoires UET Lahore, Pakistan.

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples

LAHORE -

STRUCTURAL ENGINEERING DIVISION

Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To, M/S S.A Sheikh & Co. Lahore

Reference # CED/TFL **2134** (Dr. M Rizwan Riaz)

Reference of the request letter # SASheikh/AB/MPKAB

Dated: 17-10-2022

Dated: 14-10-2022

Tension Test Report (Page -1/1)

Date of Test 18-10-2022 Gauge length 8 inches

Description Plain Steel Bar Tensile Test

Sr. No.	M Diameter/		Area (mm²)		Yield load	Breaking Load	Yield Stress (MPa)	Ultimate Stress (MPa)	Elongation	% Elongation	Remarks	
	(kg/m)	Nominal (inch)	Actual (mm)	Nominal	Actual	(kg)	(kg)	Actual	Actual	(inch)	%	1
1	8.806	1.50	37.79		1121.8	48200	80200	422	701	1.50	18.8	
-	•	-	ı	-	-	ı	-	-	1	•	-	
-	•	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	
-	•	-	ı	-	-	ı	-	-	1	•	-	
-	•	-	ı	-	-	ı	-	-	1	•	-	
				N	ote: only	one samp	ole for ten	sile test			1	
	Bend Test											

I/C Testing Laboratoires UET Lahore, Pakistan.

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To, M/S PiTech Engineering Solutions Lahore

Reference # CED/TFL **2136** (Dr. M Rizwan Riaz)

Reference of the request letter # Nil

Dated: 18-10-2022

Tension Test Report (Page - 1/2)

Date of Test 18-10-2022 Gauge length 8 inches

Description Aluminum Strip Tensile Test

Sr. No.	Designation	Size of Strip	X Section Area	Yield load	Breaking Load	Yield Stress	Ultimate Stress	. Elongation	% Elongation	Remarks
	(mm)	(mm)	(mm ²)	(kg)	(kg)	(MPa)	(MPa)	(in)		
1	30	40.20x30.50	1226.10	30300	35100	242	281	1.00	12.50	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
		T	`Only (One Sam	ple for Te	nsile Test		T	T	
	Bend Test									
	Delia 16st									

I/C Testing Laboratoires UET Lahore, Pakistan.

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To, M/S PiTech Engineering Solutions Lahore

Reference # CED/TFL **2136** (Dr. M Rizwan Riaz)

Reference of the request letter # Nil

Dated: 18-10-2022

Tension Test Report (Page - 2/2)

Date of Test 18-10-2022 Gauge length 8 inches

Description Steel Strip Tensile Test as per ASTM A36

Sr. No.	Designation	Size of Strip	X Section Area	Yield load	Breaking	Yield Stress	Ultimate Stress	Elongation	% Elongation	Remarks
	(mm)	(mm)		(kg)	(kg)	(MPa)	(MPa)	(in)		
1	30	42.40x29.90	1267.76	38700	61200	299	474	2.20	27.50	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
_	-	-	-	-	-	-	-	-	-	
_	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
			`Only (One Sam	ple for Te	nsile Test				
				D.	- 1 T4					
	Bend Test									

I/C Testing Laboratoires UET Lahore, Pakistan.

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples