



STRUCTURAL ENGINEERING DIVISION
Test Floor Laboratory
Department of Civil Engineering
University of Engineering and Technology Lahore, 54890
Pakistan. Ph: 92-42-99029202

Ref: CED/TFL/09/1918

Dated: 09-09-2022

Dated of Test: 14-09-2022

To

GM Development
Vision Developers Pvt. Ltd.
Park View City Lahore

Subject: **TESTING OF R.C.C. PIPE [ASTM-C76 - 08a]**

Reference to your letter No. Nil, dated 08.09.2022 on the subject cited above. Two R.C.C. Pipes as received by us have been tested. The results are tabulated as under.

Sr. No	Nominal Size	Total Length	Loaded Length	External Diameter	Internal Diameter	Wall Thickness	Proof load	Ultimate Load	Proof Stress	Ultimate Stress
	(inch)	(foot)	(foot)	(inch)	(inch)	(inch)	(kg)	(kg)	Pound/Linear foot/foot	Pound/Linear foot/foot
1	9	7.74	7.28	12.64	8.95	1.85	11000	17500	4470	7111
2	9	7.73	7.32	12.40	8.85	1.78	13000	18500	5311	7558

I/C Testing Laboratoires
UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site
http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2- The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples