

## STRUCTURAL ENGINEERING DIVISION

# Test Floor Laboratory Department of Civil Engineering University of Engineering and Technology Lahore, 54890 Pakistan. Ph: 92-42-99029202

To,

Assistant Director Defence Housing Authority Gujranwala (Construction of Villas (Block C))

Reference # CED/TFL <u>3221 (Dr. Usman Akmal)</u>

Reference of the request letter # 111/3/AD Bldgs/Gen/46

Dated: 18-05-2023

Dated: 17-05-2023

**Tension Test Report** (Page -1/1)

Date of Test 18-05-2023 Gauge length 8 inches

Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Sr. No.	Weight	Diameter/ Size		Area (in²)		Yield load	Breaking Load	Yield Stress (psi)		Ultimate Stress (psi)		Elongation	% Elongation	Remarks	
	(lbs/ft)	Nominal (#)	Actual (inch)	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Nominal	Actual	(inch)	% E	R	
1	0.363	3	0.369	0.11	0.107	3200	5200	64200	66030	104200	107300	1.30	16.3	SJ	
2	0.365	3	0.370	0.11	0.107	3000	4900	60200	61560	98200	100600	1.10	13.8	S.J. Steel	
-	-	-	-	-	-	-	-	-	-	-	-	-	-		
-	-	-	-	-	-	-	-	-	-	-	-	-	-		
-	-	-	-	-	-	-	-	-	-	-	-	-	-		
-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	Note: only two samples for tensile and one sample for bend test														
112	Bend Test														
#3	Bar Ben	d Test	Ihrough	1 180° 19	s Satisfa	ictory									

I/C Testing Laboratoires UET Lahore, Pakistan.

#### Note:

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing\_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



# STRUCTURAL ENGINEERING DIVISION

Test Floor Laboratory
Department of Civil Engineering
University of Engineering and Technology Lahore, 54890
Pakistan. Ph: 92-42-99029202

I/C Testing Laboratoires UET Lahore, Pakistan.

### Note:

- 1- You can See your reports On Internet in the following web site http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing\_reports
- 2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples