



STRUCTURAL ENGINEERING DIVISION
Test Floor Laboratory
Department of Civil Engineering
University of Engineering and Technology Lahore, 54890
Pakistan. Ph: 92-42-99029202

To,
M/S Vision Developers
Lahore

Reference # CED/TFL **4079** (Dr. Safer Abbass)
Reference of the request letter # 29

Dated: 19-10-2023
Dated: 18-10-2023

Tension Test Report (Page -1/1)

Date of Test 20-10-2023
Gauge length 8 inches
Description Deformed Steel Bar Tensile and Bend Test as per ASTM-A615

Sr. No.	Weight	Diameter/ Size		Area (in ²)		Yield load	Breaking Load	Yield Stress (psi)		Ultimate Stress (psi)		Elongation	% Elongation	Remarks
	(lbs/ft)	Nominal (#)	Actual (inch)	Nominal	Actual	(kg)	(kg)	Nominal	Actual	Nominal	Actual	(inch)		
1	0.367	3	0.370	0.11	0.108	3300	5100	66200	67520	102200	104400	1.40	17.5	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Note: only one sample for tensile and one sample for bend test														
Bend Test														
#3 Bar Bend Test Through 180° is Satisfactory														

I/C Testing Laboratoires
UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site
http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2- The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



STRUCTURAL ENGINEERING DIVISION
Test Floor Laboratory
Department of Civil Engineering
University of Engineering and Technology Lahore, 54890
Pakistan. Ph: 92-42-99029202

To,

Sub Divisional Officer
Highway Sub Division Sohawa
“Dualization of Dina Mangla Road Length 12.83 km, District Jhelum (Group no. 2
Construction of Bridge at Pandori)”

Reference # CED/TFL **4083** (Dr. Safer Abbass)
Reference of the request letter # 425/S

Dated: 20-10-2023
Dated: 19-10-2023

Tension Test Report (Page -1/4)

Date of Test 20-10-2023
Gauge length 640 mm
Description Steel Strand Tensile Test as per ASTM A-416-94a

Sr. No.	Nominal Diameter	Nominal Weight	Measured weight	Yield strength clause (6.3)		Breaking strength clause (6.2)		Young's Modulus of Elasticity "E"	% Elongation	Remarks / Coil No.
	(mm)	(kg/km)	(kg/km)	(kg)	(kN)	(kg)	(kN)	GPa		
1	12.70 (1/2")	780.0	781.0	17700	173.64	19600	192.28	198	>3.50	xx
2	12.70 (1/2")	780.0	782.0	17700	173.64	19700	193.26	199	>3.50	xx
3	12.70 (1/2")	780.0	774.0	17600	172.66	19600	192.28	199	>3.50	xx
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
-	-	-	-	-	-	-	-	-	-	
Only three samples for Test										

Note:

1. Modulus of Elasticity is based on nominal steel area of the steel strand vide clause 13.3 of ASTM – A416a
2. Load versus percentage strain graphs are attached

I/C Testing Laboratories
UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site
http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
2. The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



STRUCTURAL ENGINEERING DIVISION
Test Floor Laboratory
Department of Civil Engineering
University of Engineering and Technology Lahore, 54890
Pakistan. Ph: 92-42-99029202

To,


Sub Divisional Officer
Highway Sub Division Sohawa
“Dualization of Dina Mangla Road Length 12.83 km, District Jhelum (Group no. 2
Construction of Bridge at Pandori)”

Reference # CED/TFL **4083** (Dr. Safer Abbass)
Reference of the request letter # 425/S

Dated: 20-10-2023

Dated: 19-10-2023

Graph (Page – 2/4)



I/C Testing Laboratories
UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site
http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2- The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



STRUCTURAL ENGINEERING DIVISION
Test Floor Laboratory
Department of Civil Engineering
University of Engineering and Technology Lahore, 54890
Pakistan. Ph: 92-42-99029202

To,


Sub Divisional Officer
Highway Sub Division Sohawa
“Dualization of Dina Mangla Road Length 12.83 km, District Jhelum (Group no. 2
Construction of Bridge at Pandori)”

Reference # CED/TFL **4083** (Dr. Safer Abbass)
Reference of the request letter # 425/S

Dated: 20-10-2023

Dated: 19-10-2023

Graph (Page – 3/4)



I/C Testing Laboratories
UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site
http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2- The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples



STRUCTURAL ENGINEERING DIVISION
Test Floor Laboratory
Department of Civil Engineering
University of Engineering and Technology Lahore, 54890
Pakistan. Ph: 92-42-99029202

To,


Sub Divisional Officer
Highway Sub Division Sohawa
“Dualization of Dina Mangla Road Length 12.83 km, District Jhelum (Group no. 2
Construction of Bridge at Pandori)”

Reference # CED/TFL **4083** (Dr. Safer Abbass)
Reference of the request letter # 425/S

Dated: 20-10-2023

Dated: 19-10-2023

Graph (Page – 4/4)



I/C Testing Laboratories
UET Lahore, Pakistan.

Note:

- 1- You can See your reports On Internet in the following web site
http://www.uet.edu.pk/faculties/facultiesinfo/civil/index.html?RID=testing_reports
- 2- The above results pertain to sample /samples supplied to this laboratory.
- 3- Sealed sample / Unsealed sample / Marked sample/Signed Samples